

CITY OF DE PERE

Water Department



925 S. Sixth Street, De Pere, WI 54115 | 920-339-4060 | www.de-pere.org

June 5, 2019

Dear Water System Customer:

In compliance with the Safe Drinking Water Act, the City of De Pere Public Works Water Utility is pleased to provide you with the attached Consumer Confidence Report (CCR).

This document provides information about the water supply to help you make informed decisions. Specific information includes where the water comes from, contaminants present in the water, and the risks our water testing and treatment are designed to identify and prevent. We are committed to provide our customers with the safest and most reliable water possible. We believe that our best partners in this process are informed customers.

If you have any questions regarding the Consumer Confidence Report, please feel free to call either of us.

Sincerely,

Scott Thoresen

Scott Thoresen, PE
Director of Public Works
(920) 339-8095

Eric Zygarlicke

Eric Zygarlicke
Water Department Supervisor
(920) 339-4063

2018 Consumer Confidence Report Data DE PERE WATER DEPARTMENT, PWS ID: 40504530

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

Dlaim ntawv tshaabzu nuav muaj lug tseemceeb heev nyob rua huv kws has txug cov dlej mej haus. Kuas ib tug paab txhais rua koj, los nrug ib tug kws paub lug thaam.

Water System Information

The City of De Pere Water Utility is proud of the water and service that we provide to our customers. This annual report provides us an opportunity to explain our operation and provides information regarding the water we supply and how it may affect your health. We hope that this information will allow you to make informed choices. We are committed to provide a safe, efficient, and reliable water system. We hope that you find this information useful and invite your questions or comments. If you would like to know more about the information contained in this report, please contact Eric Zygarlicke at (920) 339-4063.

Opportunity for input on decisions affecting your water quality

The City water utility is operated and managed by the Board of Public Works. The Board of Public Works meets on the second Monday of every month at 7:30 PM. The meetings are held in the Council Chambers of City Hall located at 335 S. Broadway. Every agenda has a “public comment” item where the general public can ask questions or speak on any subject matter.

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

Source ID	Source	Depth (in feet)	Status
3	Groundwater	794	Emergency
4	Groundwater	871	Emergency
5	Groundwater	863	Emergency
6	Groundwater	787	Emergency
7	Purchased Surface Water		Active
8	Purchased Surface Water		Active
9	Purchased Surface Water		Active

Purchased Water

PWS ID	PWS Name
43602878	Central Brown County Water Authority
43603648	Manitowoc Waterworks

Educational Information

The sources of drinking water both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Definitions

Term Definition

AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)

Detected Contaminants in the Distribution System

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

Disinfection Byproducts

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2018)	Violation	Typical Source of Contaminant
HAA5 (ppb)	DBP-1	60	60	13	11	01/13/2013	No	By-product of drinking water chlorination
TTHM (ppb)	DBP-1	80	0	21.1	16.8	01/13/2013	No	By-product of drinking water chlorination
HAA5 (ppb)	DBP-2	60	60	14	10	01/13/2013	No	By-product of drinking water chlorination
TTHM (ppb)	DBP-2	80	0	22.0	16.8	01/13/2013	No	By-product of drinking water chlorination
HAA5 (ppb)	DBP-3	60	60	16	11	01/13/2013	No	By-product of drinking water chlorination
TTHM (ppb)	DBP-	80	0	26.2	20.1	01/13/2013	No	By-product of

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2018)	Violation	Typical Source of Contaminant
	3							drinking water chlorination
HAA5 (ppb)	DBP-4	60	60	17	12	01/13/2013	No	By-product of drinking water chlorination
TTHM (ppb)	DBP-4	80	0	28.6	20.9	01/13/2013	No	By-product of drinking water chlorination
HAA5 (ppb)	B-17	60	60	23	13 - 22		No	By-product of drinking water chlorination
TTHM (ppb)	B-17	80	0	48.2	23.5 - 56.8		No	By-product of drinking water chlorination
HAA5 (ppb)	B-31	60	60	24	14 - 18		No	By-product of drinking water chlorination
TTHM (ppb)	B-31	80	0	48.2	27.4 - 50.5		No	By-product of drinking water chlorination
HAA5 (ppb)	B-32	60	60	23	18 - 28		No	By-product of drinking water chlorination
TTHM (ppb)	B-32	80	0	58.4	31.2 - 68.7		No	By-product of drinking water chlorination
HAA5 (ppb)	DP-5	60	60	29	16 - 28		No	By-product of drinking water chlorination
TTHM (ppb)	DP-5	80	0	53.8	23.6 - 42.9		No	By-product of drinking water chlorination

Lead and Copper

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2018)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.3200	0 of 30 results	6/7/2017	No	Corrosion of household

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2018)	Violation	Typical Source of Contaminant
				were above the action level.			plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	2.20	2 of 30 results were above the action level.	6/9/2017	No	Corrosion of household plumbing systems; Erosion of natural deposits

Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. De Pere Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Health Effects for Any Contaminants with Action Level Exceedances

Contaminant Health Effects

LEAD Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Detected Contaminants from Purchased Water

Our water system purchases water from Manitowoc Public Utility through the Central Brown County Water Authority. In addition to the detected contaminants listed above, these are the results from Manitowoc.

Inorganic Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2018)	Violation	Typical Source of Contaminant
ARSENIC (ppb)	10	n/a	1	1	03/09/2017	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM (ppm)	2	2	0.02	0.02	03/09/2017	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE (ppm)	4	4	0.64	0.64	03/09/2017	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NICKEL (ppb)	100		3	3	03/09/2017	No	Nickel occurs naturally in soils, ground water and surface waters and is often used in electroplating, stainless steel and alloy products.
NITRATE (N03-N) (ppm)	10	10	0.47	0.47		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radioactive Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2018)	Violation	Typical Source of Contaminant
RADIUM, (226 + 228) (pCi/l)		5	0	1.5	1.4 - 1.5	6/1/2015	No	Erosion of natural deposits

Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. EPA required us to participate in this monitoring.

Contaminant (units)	Level Found	Range	Sample Date (if prior to 2018)
SODIUM (ppm)	8.2	8.2	
SULFATE (ppm)	21	21	
CHROMIUM (ppb)	0.2	0.2	2014-2015 MANITOWOC UCMR 3
CHROMIUM-6 (ppb)	0.2	0.2	2014-2015 MANITOWOC UCMR 3
STRONTIUM (ppb)	120	110-120	2014-2015 MANITOWOC UCMR 3
VANADIUM (ppb)	0.3	0.2-0.3	2014-2015 MANITOWOC UCMR 3
MANGANESE (ppb)	0.7	0.7	2018 MANITOWOC UCMR 4
HAA5 (ppb)	27	10.7-27	2018 DE PERE UCMR 4
HAA6Br (ppb)	16.5	9.7-16.5	2018 DE PERE UCMR 4
HAA9 (ppb)	41.8	20.5-41.8	2018 DE PERE UCMR 4

Turbidity Monitoring

In accordance with s. NR 810.29, Wisconsin Administrative Code, the treated surface water is monitored for turbidity to confirm the effectiveness of our filtration system. Turbidity is a measure of the cloudiness of water. During the year, the highest single, entry point turbidity measurement was 0.05 NTU.

Water System News

During 2018, the City continued our replacement of older water lines focusing on those in areas where we will be reconstructing roads or are experiencing excessive water main breaks. The water main was replaced in the following areas in 2018:

- Bruss Street – Erie Street to Mt Olivet Drive;
- Mt Olivet Drive – Mayfair Street to Jordan Road;
- Rebman Street – Mt Olivet Drive to Jordan Road;
- Highview Street – Jordan Road to Zurich Street;
- St. Josephs Street – Lourdes Avenue to the Cul-de-Sac;
- Helena Street – St. Josephs Street to Suburban Drive;
- South Erie Street – Merrill Street to George Street;
- Charles Street – Ontario Street to Webster Avenue;
- Main Avenue – Tenth Street to Lawrence Drive; and
- Enterprise Drive – Heritage Road to Prosper Street.

In addition, the City installed new water main in the following areas:

- Lawrence Drive – Main Avenue to the North (Cul-de-Sac);
- Pelican Landing – North Broadway Street;
- Southbridge Estates – Bridge Port Circle;
- Charles Street – Michigan Street to Huron Street; and
- Rockland Road – Destiny Drive to Enterprise Drive.

The City also continued with its annual hydrant replacement and City wide cross connection inspection programs during 2018.

In 2019, the City will continue to replace older water lines in areas with scheduled reconstruction/resurfacing, including:

- Adams Street – George Street to Charles Street;
- Cook Street – Erie Street to Robin Street;
- James Street – Front Street to Broadway Street;
- Hockers Street – Erie Street to Tanager Trail;
- Robin Street – Mayfair Street to Hockers Street;
- Silver Court – Silver Street to Cul-de-Sac;
- Silver Street – Mayfair Street to Cardinal Street;
- Star Street – Cook Street to Hockers Street;
- Washington Street – George Street to Charles Street;
- Enterprise Drive – Prosper Street to 600' South of Prosper Street; and
- Prosper Street – Enterprise Drive to Broadway Street.

In addition, the City will be installing new water main in the following areas:

- Pine Trail Crossing – Diversity Drive and Scarlet Oak Trail;
- Ryan Road – Diversity Drive to 450' South of Diversity Drive; and
- Garrity's Glen Subdivision.

In 2019, the City will also conduct the following:

- A leak detection survey on the entire water distribution system;
- An inspection of the Merrill Water Tower, Matthew Water Tower, and the 9th Street Reservoir;

- Cleaning and coating repair of Matthew Water Tower;
- Residential, commercial, and industrial cross connection inspections, conducted by Hydro Corp.;
and
- Continue installing the automated meter reading system for all new construction.

If you have any questions you may contact Eric Zygarlicke, Water Department Supervisor at 339-4063 or Scott Thoresen, Director of Public Works at 339-8095 or Larry Delo, City Administrator, and De Pere's representative on the water authority at 339-4044.