

CITY OF DE PERE

Engineering Division

925 S. Sixth Street, De Pere, WI | 920-339-4061 | www.deperewi.gov/engineering



February 27, 2023

ADDENDUM NO. 1
PROJECT 23-04
KINGSTON PRESERVE UTILITY AND STREET CONSTRUCTION

TO: Prospective Bidders

FROM: City of De Pere

Notice is hereby given that the contract documents for the Project 23-04 are amended as hereinafter set forth. If you will be submitting a bid for Project 23-04, you must sign this addendum and include it with your submittal.

This addendum consists of 2 pages.

CHANGES TO PROJECT BID DOCUMENTS:

1. Section 00 41 13, Bid Form, update as follows:
 - a. Under Bid Item ST-22, delete the following:
"Relocate or"

New RCP endwalls are required for this bid item.

CHANGES TO GENERAL REQUIREMENTS:

1. Section 01 10 00, Summary of Work, update as follows:
 - a. Under 1.4, Work Sequence/Schedule, insert the following:
"E. Sanitary sewer and water main are to be extended across Lawrence Drive within 14 calendar days once it is closed and a detour established. If concrete restoration of the intersection begins within seven calendar days after the utility installation across the intersection is completed, the detour may remain in place. If concrete restoration is completed later, the detour shall be taken down and trenches maintained."

2. Section 01 22 02, Measurement and Payment Storm Sewer, update as follows:
- Under 1.9 Flared End Section, A., delete 4 and 4.a. The endwalls are not RCP. New RCP endwalls are required.

Sincerely,

DEPARTMENT OF PUBLIC WORKS



Eric P. Rakers, P.E.
City Engineer



Acknowledged by: _____ Date: _____