

CITY OF DE PERE

PROJECT

26-18

COMMUNITY CENTER AIR HANDLER UPGRADE

BID DATE:
MARCH 19, 2026
@ 1:00 PM

Bid documents, including plans and specifications, are available for download at www.QuestCDN.com. The QuestCDN website can also be accessed through the City website at www.deperewi.gov/projects or by pressing the *Projects* icon at the bottom of any City website page. Download cost is \$22 for each contract. Bidders will be charged an additional fee of \$42 to submit a bid electronically. Bidding documents may be viewed on the QuestCDN website or at the Municipal Service Center, 925 S. Sixth Street, De Pere, WI 54115.

Bid Tabs must be verified by staff prior to posting and will be available for viewing on the website within 7 days following the bid opening. Award information will be pending until approved by the Common Council.

SECTION 00 01 10

TABLE OF CONTENTS

INTRODUCTORY INFORMATION

| <u>Section</u> | <u>Title</u> |
|----------------|----------------------|
| 00 00 01 | PROJECT MANUAL COVER |
| 00 01 10 | TABLE OF CONTENTS |

PROJECT BID DOCUMENTS

| <u>Section</u> | <u>Title</u> |
|----------------|------------------------------|
| 00 11 13 | ADVERTISEMENT TO BID |
| 00 21 13 | INSTRUCTIONS TO BIDDERS |
| 00 41 13 | BID FORM |
| 00 41 43 | BID SCHEDULE |
| 00 43 13 | BID BOND |
| 00 43 36 | TABULATION OF SUBCONTRACTORS |

CONTRACTING REQUIREMENTS

| <u>Section</u> | <u>Title</u> |
|----------------|---------------------------------------|
| 00 51 00 | NOTICE OF AWARD |
| 00 52 13 | CONTRACT |
| 00 55 00 | NOTICE TO PROCEED |
| 00 61 13 | PAYMENT BOND |
| 00 61 16 | PERFORMANCE BOND |
| 00 62 76 | APPLICATION FOR PAYMENT |
| 00 65 16 | CERTIFICATE OF SUBSTANTIAL COMPLETION |

DIVISION 1 GENERAL REQUIREMENTS

| <u>Section</u> | <u>Title</u> |
|----------------|--|
| 01 10 00 | SUMMARY OF WORK |
| 01 22 05 | MEASUREMENT AND PAYMENT SPECIAL CONSTRUCTION |
| 01 29 00 | PAYMENT PROCEDURES |
| 01 32 33 | CONSTRUCTION PHOTOGRAPHS |
| 01 33 00 | SUBMITTALS |

EXHIBITS

| | | |
|---|--------------------------------|---------|
| A | HVAC MASTER SPECIFICATIONS | 7 PAGES |
| B | AIR HANDLER UNIT UPGRADE PLANS | 5 PAGES |
| C | EXISTING SITE CONDITIONS | 1 PAGE |

CITY OF DE PERE 2025 STANDARD SPECIFICATIONS

CONTRACTING REQUIREMENTS

| <u>Section</u> | <u>Title</u> |
|----------------------|--|
| 00 70 00 | GENERAL CONDITIONS (See City of De Pere 2025 Standard Specifications) |
| DIVISION 31 – | EARTHWORK (See City of De Pere 2025 Standard Specifications) |
| DIVISION 32 – | EXTERIOR IMPROVEMENTS (See City of De Pere 2025 Standard Specifications) |
| DIVISION 33 – | UTILITIES (See City of De Pere 2025 Standard Specifications) |

SECTION 00 11 13

FEBRUARY 27, 2026 – MARCH 6, 2026

CITY OF DE PERE

ADVERTISEMENT TO BID

PROJECT 26-18

COMMUNITY CENTER AIR HANDLER UPGRADE

Online bids will be received and accepted for Project 26-18 Community Center Air Handler Upgrade via the online electronic bidding service through QuestCDN.com, until 1:00 PM, Thursday, March 19, 2026, at which time they will be publicly accepted, displayed and read aloud.

Project 26-18 for which proposals are being sought includes:

- Demolition of existing supply fan and air handling unit
- Provide concrete pad
- Provide fans and air chilling unit and associated appurtenances

Complete digital project bidding documents are available for viewing and/or downloading at www.QuestCDN.com or may be examined at the office of the Director of Public Works. Digital plan documents may be downloaded for \$22 by inputting Quest project #10084824 on Quest's Project Search page. Project documents must be downloaded from QuestCDN which will add your company to the Planholder List and allow access to vBid online bidding for the submittal of your bid. Bidders will be charged an additional fee of \$42 to submit a bid electronically. The QuestCDN website can also be accessed through the City website at www.deperewi.gov/projects or by pressing the *Projects* icon at the bottom of any City website page. Contact QuestCDN Customer Support at 952-233-1632 or info@questcdn.com for assistance in membership registration, downloading digital project information and vBid online bid submittal questions.

Each proposal shall be accompanied by a bid bond in an amount equal to five percent (5%) of the bid, payable to the City of De Pere, as a guarantee that if the bid is accepted, the bidder will execute a contract and furnish a contract bond as set forth in the General Conditions of the City of De Pere. In case the bidder fails to file such contract and bond, the amount of the bid bond shall be forfeited to the City of De Pere as liquidated damages.

An optional pre-bid meeting will be held on Tuesday, March 10, 2026 at 9:00 AM CST on the first floor of the City of De Pere Community Center, 600 Grant Street, De Pere, WI 54115.

The letting of the contract is subject to the provisions of the following Wisconsin Statutes:

Section 62.15 regarding Public Works.

**Project 26-18
Community Center Air Handler Upgrade**

City of De Pere

Section 66.0901(3) regarding Prequalification of Contractor.

Each bidder shall pre-qualify by submitting proof of responsibility on forms furnished by the Director of Public Works. Such forms shall be filed with the Director of Public Works no later than 4:00 PM, Monday, March 16, 2026. Prospective bidders who have previously submitted such forms subsequent to January 1, 2026 will not be required to separately submit such forms for this project.

The City of De Pere reserves the right to reject any or all bids, to waive any informalities in bidding and to accept any proposal which the Common Council deems most favorable to the interest of the City of De Pere.

Dated this 27th day of February 2026.

Board of Public Works
City of De Pere
Eric Rakers, P.E.
City Engineer

Project 26-18

SECTION 00 21 13

INSTRUCTIONS TO BIDDERS

ARTICLE 1 – DEFINED TERMS

- 1.1 Terms used in these Instructions to Bidders have the meanings indicated in the General Conditions. Additional terms used in these Instructions to Bidders have the meanings indicated below:
None

ARTICLE 2 – COPIES OF BIDDING DOCUMENTS

- 2.1 Complete sets of the Bidding documents in the number and for the deposit sum, if any, stated in the Advertisement to Bid may be obtained as stated in the Advertisement for bids.
- 2.2 Complete sets of Bidding Documents shall be used in preparing Bids; Owner does not assume any responsibility for errors or misinterpretations resulting from the use of incomplete sets of Bidding Documents.
- 2.3 Owner, in providing the Bidding Documents on the terms stated in the Advertisement for Bids, does so only for the purpose of obtaining Bids for the Work and does not confer a license or grant for any other use.

ARTICLE 3 – QUALIFICATIONS OF BIDDERS

- 3.1 In accordance with Section 66.0901(3), each bidder shall pre-qualify by submitting proof of responsibility on forms furnished by the Director of Public Works. Such forms shall be filed with the Director of Public Works as stated in the Advertisement for Bids. Prospective bidders who have previously submitted such forms after January 1st of this year will not be required to separately submit such form for this project.

ARTICLE 4 – EXAMINATION OF BIDDING DOCUMENTS, OTHER RELATED DATA AND SITE

- 4.1 Provisions concerning responsibilities for the adequacy of data furnished to prospective Bidders with Underground Facilities, and possible changes in the Bidding Documents due to differing or unanticipated conditions appear in the General Conditions.
- 4.2 On request, Owner will provide Bidder access to the Site to conduct such examinations, investigations, explorations, test, and studies as Bidder deems necessary for submission of a Bid. Bidder shall fill all holes and clean up and restore the Site to its former condition upon completion of such explorations, investigations, test, and studies. Bidder shall comply with all applicable laws and Regulations relative to excavation and utility locates.
- A. An optional pre-bid meeting will be held on Tuesday, March 10, 2026 at 9:00 AM CST on the first

floor of the City of De Pere Community Center, 600 Grant Street, De Pere, WI 54115.

- 4.3 Reference is made to Section 01 10 00: Summary of Work, for work that will be completed and for the identification of the general nature of other work that is to be performed at the Site by Owner or others (such as utilities and other prime contractors) that relates to the Work contemplated by these Bidding Documents. On request, Owner will provide to each Bidder for examination access to or copies of Contract Documents (other portions thereof related to price) for such other work.
- 4.4 It is the responsibility of each Bidder before submitting a Bid to:
- A. Examine and carefully study the Bidding Documents, the other related data identified in the Bidding Documents, and any Addenda;
 - B. Visit the Site and become familiar with and satisfy Bidder as to the general, local, and Site conditions that may affect cost, progress, and performance of the Work;
 - C. Become familiar with and satisfy Bidder as to all federal, state, and local Laws and Regulations that may affect cost, progress, and performance of the Work;
 - D. Obtain and carefully study (or accept consequences of not doing so) all examinations, investigations, explorations, tests, studies, and data concerning conditions (surface, subsurface, and Underground Facilities) at or contiguous to the Site which may affect cost, progress, or performance of the Work or which relate to any aspect of the means, methods, techniques, sequences, and procedures of construction to be employed by Bidder, including applying any specific means, methods, techniques, sequences, and procedures of construction expressly required by the Bidding Documents, and safety precautions and programs incident thereto;
 - E. Agree at the time of submitting its Bid that no further examinations, investigations, explorations, tests, studies, or data are necessary for the determination of its Bid for performance of the Work at the price(s) bid and within the times and in accordance with the other terms and conditions of the Bidding Documents;
 - F. Become aware of the general nature of the work to be performed by Owner and others at the Site that relates to the Work as indicated in the Bidding Documents;
 - G. Correlate the information known to Bidder, information and observations obtained from visits to the Site, reports and drawings identified in the Bidding Documents, and all additional examinations, investigations, explorations, tests, studies, and data with the Bidding Documents;
 - H. Promptly give Engineer written notice of all conflicts, errors, ambiguities, or discrepancies, that bidder discovers in the Bidding Documents and confirm that the written resolution thereof by Engineer is acceptable to Bidder; and
 - I. Determine that the Bidding Documents are generally sufficient to indicate and convey

understanding of all terms and conditions for the performance of the Work.

- 4.5 The submission of a Bid will constitute an incontrovertible representation by Bidder that Bidder has complied with every requirement of this Article 4, that without exception the Bid is premised upon performing and furnishing the Work required by the Bidding Documents and applying any specific means, methods, techniques, sequences, and, procedures of construction that may be shown or indicated or expressly required by the Bidding Documents, that Bidder has given Engineer written notice of all conflicts, errors, ambiguities, and discrepancies that Bidder has discovered in the Bidding Documents and the written resolutions thereof by Engineer are acceptable to Bidder, and that the Bidding Documents are generally sufficient to indicate and convey understanding of all terms and conditions for performing and furnishing the Work.

ARTICLE 5 – SITE AND OTHER AREAS

- 5.1 The Site is identified in the Bidding Documents. Easements for permanent structures or permanent changes in existing facilities are to be obtained and paid for by Owner unless otherwise provided in the Bidding Documents. All additional lands and access thereto required for temporary construction facilities, construction equipment, or storage of materials and equipment to be incorporated in the Work are to be obtained and paid for by Contractor.

ARTICLE 6 – INTERPRETATIONS AND ADDENDA

- 6.1 All questions about the meaning or intent of the Bidding Documents are to be submitted to Engineer in writing. Interpretations or clarifications considered necessary by Engineer in response to such questions will be issued by Addenda mailed or delivered to all parties recorded by Engineer as having received the Bidding Documents. Questions received less than ten days prior to the date for opening of Bids may not be answered. Only questions answered by Addenda will be binding. Oral and other interpretations or clarifications will be without legal effect.
- 6.2 Addenda may be issued to clarify, correct, or change the Bidding Documents as deemed advisable by Owner and Engineer.

ARTICLE 7 – BID SECURITY

- 7.1 A Bid shall be accompanied by Bid security made payable to Owner in an amount of five percent (5%) of Bidder's maximum Bid price and in the form of a certified check or bank money order or Bid bond (on the form attached) issued by a surety meeting the requirements of the General Conditions. Submittal of a Bid Bond on a form other than the Bid Bond form included in the Bidding Documents may be cause for rejection of Bid. The fully executed bid bond must be uploaded into QuestCDN. If the bidder elects to furnish bid security other than a bid bond, the bid security must be submitted in a sealed envelope enclosed in a separate package plainly marked on the outside with the notation "BID SECURITY" along with the project number and name and addressed to the Board of Public Works of the City of De Pere, Municipal Service Center, 925 S. Sixth Street, De Pere, WI 54115 **prior to the deadline for submission of bids.**

- 7.2 The Bid security of the Successful Bidder will be retained until such Bidder has executed the Contract documents, furnished the required contract security and met the other conditions of the Notice of Award, whereupon the Bid security will be returned. If the Successful Bidder fails to execute and deliver the Contract Documents and furnish the required contract security within fifteen (15) days after the Notice of Award, Owner may annul the Notice of Award and the Bid security of that Bidder will be forfeited. The Bid security of other Bidders whom Owner believes to have a reasonable chance of receiving the award may be retained by Owner per the General Conditions.
- 7.3 Bid security of other Bidders whom Owner believes do not have a reasonable chance of receiving the award will be returned within seven days after the Bid opening.

ARTICLE 8 – CONTRACT TIMES

- 8.1 The number of days within which, or the dates by which, Milestones are to be achieved and the Work is to be substantially completed and ready for final payment are set forth in the Bid Form and Summary of Work.

ARTICLE 9 – LIQUIDATED DAMAGES

- 9.1 Provisions for liquidated damages are set forth in the General Conditions.

ARTICLE 10 – SUBSTITUTE AND “OR-EQUAL” ITEMS

- 10.1 The Contract, if awarded, will be on the basis of materials and equipment specified or described in the Bidding Documents without consideration of possible substitute or “or-equal” items. Whenever it is specified or described in the Bidding Documents that a substitute or “or-equal” item of material or equipment may be furnished or used by Contractor if acceptable to Engineer, application for such acceptance will not be considered by Engineer until after the Effective Date of the Bid Form and Summary of Work.

ARTICLE 11 – SUBCONTRACTORS, SUPPLIERS, AND OTHERS

- 11.1 The Bidder shall submit with the Bid to Owner a list of all such Subcontractors, Suppliers, individuals, or entities proposed for those portions of the Work for which such identification is required. Such list shall be accompanied by an experience statement with pertinent information regarding similar projects and other evidence of qualification for each such Subcontractor, Supplier, individual, or entity, Owner may, before the Notice of Award is given, request apparent Successful Bidder to submit a substitute, in which case apparent Successful Bidder shall submit an acceptable substitute, Bidder’s Bid price will be increased (or decreased) by the difference in cost occasioned by such substitution, and Owner may consider such price adjustment in evaluating Bids and making the Contract award.

- 11.2 If apparent Successful Bidder declines to make any such substitution, Owner may award the Contract to the next lowest Bidder that proposed to use acceptable Subcontractors, Suppliers, individuals, or entities. Declining to make requested substitutions will not constitute grounds for forfeiture of the Bid security of any Bidder. Any Subcontractor, Supplier, individual, or entity so listed and against which Owner makes no written objection prior to the giving of the Notice of Award will be deemed acceptable to Owner subject to revocation of such acceptance after the Effective Date of the Agreement.
- 11.3 Contractor shall not be required to employ any Subcontractor, Supplier, individual, or entity against whom Contractor has reasonable objection.

ARTICLE 12 – PREPARATION OF BID

- 12.1 The Bid form is included with the Bidding documents.
- 12.2 All blanks on the Bid Form shall be completed by printing in ink or by typewrite and the Bid signed in ink. Erasures or alterations shall be initialed in ink by the person signing the Bid Form. A Bid price shall be indicated for each alternative, and unit price item listed therein, or the words “No Bid,” “No Change,” or “Not Applicable” entered.
- 12.3 A Bid by a corporation shall be executed in the corporate name by the president or a vice-president or other corporate officer accompanied by evidence of authority to sign. The corporate seal shall be affixed and attested by the secretary or an assistant secretary. The corporate address and state of incorporations shall be shown below the seal.
- 12.4 A Bid by a partnership shall be executed in the partnership name and signed by a partner (whose title must appear under the signature), accompanied by evidence of authority to sign. The official address of the partnership shall be shown below the signature.
- 12.5 A Bid by a limited liability company shall be executed in the name of the firm by a member and accompanied by evidence of authority to sign. The state of formation of the firm and the official address of the firm shall be shown below the signature.
- 12.6 A Bid by an individual shall show the Bidder’s name and official address.
- 12.7 A Bid by a joint venture shall be executed by each joint venture in the manner indicated on the Bid Form. The official address of the joint venture shall be shown below the signature.
- 12.8 All names shall be typed or printed in ink below the signatures.
- 12.9 The Bid shall contain an acknowledgement of receipt of all Addenda, the numbers of which shall be filled in on the Bid Form.
- 12.10 The address and telephone number for communications regarding the Bid shall be shown.

- 12.11 The Bid shall contain evidence of Bidder's authority and qualification to do business in the state where the Project is located or covenant to obtain such qualification prior to award of the Contract. Bidder's state contractor license number, if any, shall also be shown on the Bid Form.

ARTICLE 13 – BASIS OF BID; COMPARISON OF BIDS

13.1 Unit Price

- A. Bidders shall submit a Bid on a unit price basis for each item of Work listed in the Bid Schedule.
- B. The total of all estimated prices will be the sum of the products of the estimated quantity of each item and the corresponding unit price. The final quantities and Contract Price will be determined in accord with the General Conditions.
- C. Discrepancies between the multiplication of units of Work and unit prices will be resolved in favor of the unit prices. Discrepancies between the indicated sum of any column of figures and the correct sum thereof will be resolved in favor of the correct sum. Discrepancies between words and figures will be resolved in favor of the words.

ARTICLE 14 – SUBMITTAL OF BID

- 14.1 A Bid shall be submitted no later than date and time prescribed and at place indicated in Advertisement for Bids and shall be submitted electronically using the QuestCDN online bidding vBid platform. No paper bids will be accepted.
- 14.2 See Bid Form for a list of documents typically required to be submitted with the Bid.

ARTICLE 15 – MODIFICATION AND WITHDRAWAL OF BID

- 15.1 A Bid may be modified or withdrawn by an appropriate document duly executed in the manner that a Bid must be executed and delivered to the place where Bids are to be submitted prior to the date and time for the opening of Bids.
- 15.2 If within 24 hours after Bids are opened, any Bidder files a duly signed written notice with Owner and promptly thereafter demonstrates to the reasonable satisfaction of Owner that there was a material and substantial mistake in the preparation of its Bid, that Bidder may withdraw its Bid, and the Bid security will be returned. Thereafter, if the Work is rebid, that Bidder will be disqualified from further bidding on the Work.

ARTICLE 16 – OPENING BIDS

- 16.1 Bids will be opened as indicated in the Advertisement to Bid. The bid opening can be viewed live via the GoToMeeting information shown below. An abstract of the amounts of the base bids and major

alternatives, if any, will be made available to bidders after opening the bids.

The bid opening can be viewed live via GoToMeeting as follows:
Please join my meeting from your computer, tablet or smartphone.

<https://meet.goto.com/345634277>

You can also dial in using your phone.
(For supported devices, tap a one-touch number below to join instantly.)

United States (Toll Free): [1 877 309 2073](tel:18773092073)

Access Code: 345-634-277

New to GoToMeeting? Get the app now and be ready when your first meeting starts:
<https://meet.goto.com/install>

ARTICLE 17 – BIDS REMAIN SUBJECT TO ACCEPTANCE

- 17.1 All bids will remain subject to acceptance for the period of time stated in the General Conditions, but Owner may, in its sole discretion, release any Bid and return the Bid security prior to the end of this period.

ARTICLE 18 – EVALUATION OF BIDS AND AWARD OF CONTRACT

- 18.1 Owner reserves the right to reject any or all Bids, including without limitation, nonconforming, nonresponsive, unbalanced, or conditional Bids. Owner further reserves the right to reject the Bid of any Bidder whom it finds, after reasonable inquiry and evaluation, to not be responsible. Owner may also reject the Bid of any Bidder if Owner believes that it would not be in the best interest of the Project to make an award to that Bidder. Owner also reserves the right to waive all informalities not involving price, time, or changes in the Work and to negotiate contract terms with the Successful Bidder.
- 18.2 More than one Bid for the same Work from an individual or entity under the same or different names will not be considered. Reasonable grounds for believing that any Bidder has an interest in more than one Bid for the Work may be cause for disqualification of that Bidder and the rejection of all Bids in which that Bidder has an interest.
- 18.3 In evaluating Bids, Owner will consider whether or not the Bids comply with the prescribed requirements, and such alternates, unit prices and other data, as may be requested in the Bid Form or prior to the Notice of Award.
- 18.4 In evaluating Bidders, Owner will consider the qualifications of Bidders and may consider the qualifications and experience of Subcontractors, Supplier, and other individuals or entities proposed

for those portions of the Work for which the identify of Subcontractors, Suppliers, and other individuals or entities must be submitted as provided in the Supplementary Conditions.

- 18.5 Owner may conduct such investigations as Owner deems necessary to establish the responsibility, qualifications, and financial ability of Bidders, proposed Subcontractors, Suppliers, individuals, or entities to perform the Work in accordance with the Contract Documents.
- 18.6 Bidder agrees to waive any claim it has or may have against the Owner and the respective employees arising out of or in connection with the administration, evaluation or recommendation of any Bid.
- 18.7 If the Contract is to be awarded, Owner will award the Contract to the lowest responsible responsive Bidder whose Bid is in the best interests of the Project.

ARTICLE 19 – CONTRACT SECURITY AND INSURANCE

- 19.1 The General Conditions set forth Owner’s requirements as to performance and payment bonds and insurance. When the Successful Bidder delivers the executed Agreement to Owner, it shall be accompanied by such bonds and a certificate of insurance.

ARTICLE 20 – SIGNING OF AGREEMENT

- 20.1 When Owner gives a Notice of Award to the Successful Bidder, it shall be accompanied by the required number of unsigned counterparts of the Agreement with the other Contract Documents which are identified in the Agreement as attached thereto. Within ten (10) days thereafter, Successful Bidder shall sign and deliver the required number of counterparts of the Agreement and attached documents to Owner. Within ten (10) days thereafter, Owner shall deliver one fully signed counterpart to Successful Bidder with a complete set of Drawings with appropriate identification.

END OF SECTION

SECTION 00 41 13

CITY OF DE PERE

BID FORM

PROJECT 26-18

This bid, submitted by the undersigned Bidder to the City of De Pere, in accordance with the Advertisement to Bid, which will be received until 1:00 PM, Thursday March 19, 2026 is to furnish and deliver all materials, and to perform and do all work on the project designated per Section 01 10 00 Summary of Work.

Bidder has examined and carefully prepared the bid from the plans and specifications and has checked the same in detail before submitting said proposal or bid; and that said bidder or bidder's agents, officer or employees have not, either directly or indirectly, entered into any agreement, participated in any collusion, or otherwise taken any action in restraint of free competitive bidding in connection with this proposal or bid.

Bidder has examined and carefully studied the Bidding Documents, other related data identified in the Bidding Documents, and the following Addenda, receipt of which is hereby acknowledged:

Addendum No.

Addendum Date

BASIS OF BID:

Bidder will complete the Work in accordance with the Contract documents for the following price(s):

As stated in the attached Unit Price Bid Schedule.

Unit Prices have been computed in accordance with the General Conditions.

Bidder acknowledges that estimated quantities are not guaranteed, and are solely for the purpose of comparison of Bids, and final payment for all Unit Price Bid items will be based on actual quantities, determined as provided in the Contract Documents.

TOTAL BID PRICE: \$ _____

**Project 26-18
Community Center Air Handler Upgrade**

City of De Pere

ATTACHMENTS TO THIS BID

The following documents are submitted with and made a condition of this Bid:

- A. Required Bid Security
- B. Unit Price Bid Schedule (Section 00 41 43)
- C. Tabulation of Subcontractors (Section 00 43 36)

BID SUBMITTAL

This Bid is submitted by _____ of _____,

The Bidder, being duly sworn, does dispose that they are an authorized representative of

Bidder, if Bidder is:

An Individual

Name (typed or printed): _____

By: _____
(Individual's signature)

Doing business as: _____

A Partnership

Partnership Name: _____

By: _____
(Signature of general partner – attach evidence of authority to sign)

Name (typed or printed): _____

A Corporation

Corporation Name: _____

State of Incorporation: _____

Type (General Business, Professional, Service, Limited Liability): _____

By: _____
(Signature – attach evidence of authority to sign)

Name (typed or printed): _____

Title: _____
(CORPORATE SEAL)

Attest _____

Date of Qualification to do business in Wisconsin is ___/___/___.

Joint Venture

Name of Joint Venture: _____

First Joint Venturer Name: _____ (SEAL)

By: _____
(Signature of first joint venture partner – attach evidence of authority to sign)

Name (typed or printed): _____

Title: _____

Second Joint Venturer Name: _____ (SEAL)

By: _____
(Signature of second joint venture partner – attach evidence of authority to sign)

Name (typed or printed): _____

Title: _____

(Each joint venturer must sign. Manner of signing for each individual, partnership, and corporation that is a party to joint venture should be in manner indicated above.)

Bidder's Business Address _____

Phone No. _____ Fax No. _____

E-mail _____

SUBMITTED on _____, 20____.

State Contractor License No. _____ (if applicable)

SECTION 00 41 43

CITY OF DE PERE

PROJECT 26-18

BID SCHEDULE – UNIT PRICE

| ITEM | ITEM DESCRIPTION | UNIT | QUANTITY | UNIT PRICE | AMOUNT BID |
|--------------------------|---|-------------|-----------------|-------------------|-------------------|
| SC-01 | Demolition of existing supply fan, DX cooling coil, refrigerant lines, existing air-cooled condensing unit and concrete pad | LS | 1 | \$ _____ | \$ _____ |
| SC-02 | Installation of new air handler system, concrete pad, electrical, and associated appurtenances | LS | 1 | \$ _____ | \$ _____ |
| TOTAL AMOUNT BID: | | | | | \$ _____ |

SECTION 00 43 13

CITY OF DE PERE

BID BOND

KNOW ALL MEN BY THESE PRESENTS: That _____,

as Principal, hereinafter called Principal, and _____,

as Surety, hereinafter called Surety, are held and firmly bound unto the City of De Pere, a municipal corporation of the State of Wisconsin, as Obligee, hereinafter called City, in the amount of _____ dollars (\$_____) for the payment whereof Principal and Surety bind themselves, their heirs, executors, administrators, successors and assigns, jointly and severally, firmly by these presence.

WHEREAS, Principal has made a proposal to the City for furnishing all materials, labor, tools, equipment and incidentals necessary to complete the work of Project 26-18 in accordance with drawings and specifications prepared by the Director of Public Works of said City, which proposal is by reference made a part hereof, and is hereinafter referred to as the BID.

NOW, THEREFORE, THE CONDITION OF THIS OBLIGATION is such that, if Principal shall be awarded the contract for said project and Principal shall enter into a contract in accordance with the BID, then this obligation shall be null and void; otherwise it shall remain in full force and effect, provided that:

1. The liability of Surety shall in no event exceed the penalty of this bond.
2. Any suits at law or proceedings, in equity brought or to be brought against Surety to recover any claim hereunder shall be executed within six (6) months from the date of this instrument.

Signed and sealed this _____ day of _____, 20_____.

In the presence of:

WITNESS

PRINCIPAL (SEAL)

WITNESS

SURETY (SEAL)

SECTION 00 51 00

NOTICE OF AWARD

(Contractor)
(Contractor Name)
(Address)
(Address)

Project Description: 26-18 Community Center Air Handler Upgrade

The City has considered the proposal submitted by you dated March 19, 2026 for the above-described project in response to its Advertisement for Bids dated February 27, 2026 and March 6, 2026.

You are hereby notified that the Common Council of the City of De Pere has accepted your bid of (Contract Amount \$_____00).

You are required to execute the Contract and furnish the required Performance Bond, Payment Bond and Certificates of Insurance within ten (10) calendar days from the date of this notice to you.

If you fail to execute said Agreement and to furnish said bonds within ten (10) days from the date of this notice, said City will be entitled to consider all your rights arising out of the City's acceptance of your bid as abandoned and as a forfeiture of your Bid Bond. The City will be entitled to such other rights as may be granted by law.

You are required to return an acknowledged copy of this NOTICE OF AWARD to the City.

Dated this _____ day of _____ 2026.

DEPARTMENT OF PUBLIC WORKS

BY: Eric P. Rakers, P.E.
City Engineer

ACCEPTANCE OF NOTICE

Receipt of the above NOTICE OF AWARD is hereby acknowledged by:

_____, this the _____ day of _____, 20__

By: _____

Title: _____

SECTION 00 52 13

CONTRACT

This Contract, made and entered into this day _____ (date to be affixed by City), by and between (Contractor Name), hereinafter called Contractor, and the City of De Pere, a municipal corporation of the State of Wisconsin, hereinafter called City.

WITNESSETH: That, in consideration of the covenants and agreements herein contained, to be performed by the parties hereto, and of the payments hereinafter agreed to be made, it is mutually agreed as follows:

ARTICLE I - SCOPE OF WORK

The Contractor shall furnish all materials and all equipment and labor necessary, and perform all work shown on the drawings and described in the specifications for the project entitled Project 26-18 Community Center Air Handler Upgrade, all in accordance with the requirements and provisions of the following documents, which are hereby made a part of this Contract:

- (a) Advertisement for Bids, dated February 27, 2026 and March 6, 2026
- (b) Drawings designated for Project 26-18 Community Center Air Handler Upgrade dated February 27, 2026.
- (c) City of De Pere 2025 Construction Specifications.
- (d) Special Provisions dated February 27, 2026.
- (e) Proposal submitted by (Contractor Name) dated March 19, 2026.
- (f) Addenda No. _____ dated _____

ARTICLE II - TIME OF COMPLETION

- (a) The work to be performed under the Contract shall be commenced within (number spelled out) (__) calendar days after receipt of written notice to proceed. The work shall be completed within (Number spelled out) (__) calendar days) or (specific calendar dates) after receipt of Notice to Proceed.
- (b) Time is of the essence with respect to the date of completion herein above stated. Failure to complete the work within the number of calendar days stated in this Article, or interim dates included in the work sequence in Section 01 10 00, Summary of Work, including any extensions granted thereto, shall entitle the City to deduct from the monies due the Contractor an amount equal to Update based on 00 70 00 - General Conditions (Page 26)(\$) per day for each calendar day of delay in the completion of the work. Such amount shall be considered and treated not as a penalty but as liquidated damages, which the City will sustain, by failure of the Contractor to complete the work within the time stated.

ARTICLE III - PAYMENT

- (a) The Contract Sum. The City shall pay to the Contractor for the performance of the Contract the amounts determined for the total number of each of the following units of work completed at the unit price stated thereafter. The number of units contained in this schedule is approximate only, and the final payment shall be made for the actual number of units that are incorporated in or made necessary by the work covered by the Contract.
- (b) Progress Payments. The City shall make payments on account of the Contract as follows:
1. On not later than the fourth Friday of every month the Contractor shall present to the City an invoice covering an estimate of the amount and proportionate value of the work done as verified by the City under each item of work that has been completed from the start of the job up to and including the fourth Friday of the preceding month, and the value of the work so completed determined in accordance with the schedule of unit prices for such items, together with such supporting evidence as may be required. This invoice shall also include an allowance for the cost of such materials and equipment required in the permanent work as have been delivered to the site but not as yet incorporated in the work.
 2. On not later than the third week of the following month, the City shall, after deducting previous payments made, pay to the Contractor 95% of the amount of the approved invoice, retaining 5% of the estimate of work done until 50% of the work has been completed. At 50% completion of the work, the previous retainage shall not yet be paid, but further partial payments shall be made in full to the contractor without additional retainage being taken unless the engineer certifies that the work is not proceeding satisfactorily. If the work is not proceeding satisfactorily, additional amounts may be retained. After substantial completion, an amount retained may be paid to the contractor, keeping retained only such amount as is needed for the remaining work.
 3. The Contractor shall notify the City in writing when all work under this Contract has been completed. Upon receipt of such notice the City shall, within a reasonable time, make the final inspection and issue a final certificate stating that the work provided for in this Contract has been completed and is accepted under the terms and conditions thereof, and that the entire balance due the Contractor as noted in said final certificate is due and payable. Before issuance of the final certificate the Contractor shall submit evidence satisfactory to the City that payrolls, material bills, and other indebtedness connected with the work under this Contract have been paid. The City shall make final payment as soon after issuance of the final certificate as practicable.

ARTICLE IV – CONTRACT DOCUMENTS

(a) Contents

1. The Contract documents consist of the following:
 - a. This Contract (pages 00 52 13-1 to 0052-13-3, inclusive).
 - b. Payment bond (pages 00 61 13-1 to 00 61 13-2, inclusive).
 - c. Performance bond (page 00 61 16-1).
 - d. General Conditions (pages 00 70 00-1 to 00 70 00-27, inclusive).

SECTION 00 55 00

NOTICE TO PROCEED

Date: _____

(CONTRACTOR NAME)
(ADDRESS)
(ADDRESS)

Project Description: 26-18 Community Center Air Handler Upgrade

You are hereby notified to commence work in accordance with the CONTRACT dated _____, within ten (10) days of this Notice. All work under this contract shall be completed within _____ (NUMBER IN WORDS) (__#) consecutive days from the start of construction or _____ (DATE) whichever comes first.

Department of Public Works

By: Eric P. Rakers, P.E.
Title: City Engineer

ACCEPTANCE OF NOTICE

Receipt of the above NOTICE TO PROCEED is hereby acknowledged by

_____, this _____ day of _____, 20 ____.
Company Name

Signature

BY: _____
Printed Name

TITLE: _____

SECTION 00 61 13

CITY OF DE PERE

PAYMENT BOND

KNOW ALL MEN BY THESE PRESENTS: That **(CONTRACTOR NAME)**, as Principal, hereinafter called Contractor, and _____, as Surety, hereinafter called Surety, are held and firmly bound unto the City of De Pere, a municipal corporation of the State of Wisconsin, as Obligee, hereinafter called the City, for the use and benefit of claimants as herein below defined in the **amount of _____ (CONTRACT AMT. SPELLED OUT) (\$_____)** for the payment whereof Contractor and Surety bind themselves, their heirs, executors, administrators, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, Contractor has by written agreement dated _____ (date to be affixed by City) entered into a contract with City for Project 26-18, in accordance with drawings and specifications prepared by the Director of Public Works of said City, which contract is by reference made a part hereof, and is hereinafter referred to as the CONTRACT.

NOW, THEREFORE, THE CONDITION OF THIS OBLIGATION is such that, if Contractor shall promptly make payments to all claimants as hereinafter defined, for all labor and material used or reasonably required for use in the performance of the CONTRACT, then this obligation shall be null and void; otherwise it shall remain in full force and effect, subject, however, to the following conditions.

1. A claimant is defined as one having a direct contract with Contractor or with a subcontractor of Contractor for labor, material, or both, used or reasonably required for use in the performance of the contract, labor and material being construed to include that part of water, gas, power, lights, heat, oil, gasoline, telephone service, or rental of equipment directly applicable to the contract.
2. The above named Contractor and Surety hereby jointly and severally agree with the City that every claimant as herein defined, who has not been paid in full before the expiration of a period of ninety (90) days after the date on which the last of such claimant's work or labor was done or performed, or materials were furnished by such claimant may sue on this bond for the use of such claimant in the name of the City, prosecute the suit to final judgment for such sum or sums as may be justly due claimant, and have execution thereon, provided, however, that the City shall not be liable for the payment of any costs or expenses of any such suit.
3. No suit or action shall be commenced hereunder by any claimant:
 - a. Unless claimant shall have given written notice to any two of the following: The Contractor, the City, or the Surety above named, within ninety (90) days after such claimant did or performed the last of the work or labor, or furnished the last of the materials for which said claim is made, stating with substantial accuracy the amount claimed and the name of the party to whom the materials were furnished, or for whom the work or labor was done or performed. Such notice shall be served by mailing the same by registered mail, postage prepaid, in an envelope addressed to the Contractor, City, or Surety, at any place where an office is regularly maintained for the transaction of business, or served in any manner in which legal process may be served in the State of Wisconsin, save that such service need not be made by a public officer.
 - b. After the expiration of one (1) year following the date on which Contractor ceased work on said CONTRACT.

**Project 26-18
Community Center Air Handler Upgrade**

City of De Pere

- c. Other than in a state court of competent jurisdiction in and for the County or other political subdivision of the state in which the project, or any part thereof, is situated, or in the United States District Court for the district in which the project, or any part thereof, is situated, and not elsewhere.

- 4. The amount of this bond shall be reduced by and to the extent of any payment or payments made in good faith hereunder, inclusive of the payment by Surety of mechanics' liens, which may be filed or recorded against said improvement, whether or not claim for the amount of such lien be presented under and against this bond.

SIGNED AND SEALED THIS _____ DAY OF _____, 20__.

In Presence of:

| | | |
|-----------|--------------|--------|
| _____ | _____ | _____ |
| (WITNESS) | (CONTRACTOR) | (SEAL) |
| _____ | _____ | _____ |
| (WITNESS) | (SURETY) | (SEAL) |

SECTION 00 61 16

CITY OF DE PERE

PERFORMANCE BOND

KNOW ALL MEN BY THESE PRESENTS: That **(CONTRACTOR'S NAME)**, as Principal, hereinafter called Contractor, and _____, as Surety, hereinafter called Surety, are held and firmly bound unto the City of De Pere, a municipal corporation of the State of Wisconsin, as Obligee, hereinafter called City, in the amount of **(AMOUNT WRITTEN OUT)** (\$ _____) for the payment whereof Contractor and Surety bind themselves, their heirs, executors, administrators, successors and assign, jointly and severally, firmly by these presents.

WHEREAS, Contractor has by written agreement dated _____ (date to be affixed by City), entered into a contract with the City for Project 26-18, in accordance with drawings and specifications prepared by the Director of Public Works of said City, which contract is by reference made a part hereof, and is hereinafter referred to as the CONTRACT.

NOW THEREFORE, THE CONDITION OF THIS OBLIGATION is such that, if the Contractor shall promptly and faithfully perform said CONTRACT, then this obligation shall be null and void; otherwise it shall remain in full force and effect.

Whenever Contractor shall be, and declared by the City to be in default under the CONTRACT, the City having performed City's obligations there under, the Surety may promptly remedy the default, or shall promptly

1. Complete the CONTRACT in accordance with its terms and conditions or
2. Obtain a bid or bids for submission to City for completing the CONTRACT in accordance with its terms and conditions, and upon determination by the City and Surety of the lowest responsible bidder, arrange for a contract between such bidder and City make available as work progresses (even though there should be a default or succession of defaults under the contract or contracts of completion arranged under this paragraph) sufficient funds to pay the cost of completion less the balance of the contract price; but not exceeding, including other costs and damages for which the Surety may be liable hereunder, the amount set forth in the first paragraph hereof. The term "balance of the contract price" as used in this paragraph shall mean the total amount payable by City to Contractor under the CONTRACT and any amendments thereto, less the amount properly paid by City to Contractor.

Any suit under this bond must be instituted before the expiration of two (2) years from the date on which final payment under the CONTRACT falls due. No right of action shall accrue on this bond to or for the use of any person or corporation other than the owner named herein or the heirs, executors, administrators or successors of City.

SIGNED AND SEALED THIS _____ DAY OF _____, 20_____.

In the Presence of:

| | | |
|-----------|--------------|--------|
| (WITNESS) | (CONTRACTOR) | (SEAL) |
| (WITNESS) | (SURETY) | (SEAL) |

SECTION 00 62 76

APPLICATION FOR PAYMENT

Contractor's Application for Payment No.

| | |
|------------------------|---------------------------|
| Application Period: | Application Date: |
| Owner: City of De Pere | Contractor: |
| | Contractor's Project No.: |

APPLICATION FOR PAYMENT

Change Order Summary

| Approved Change Orders | | | 1. ORIGINAL CONTRACT PRICE:..... | |
|-------------------------------------|-----------|------------|--|--------|
| Number | Additions | Deductions | 2. Net change by Change Orders and Written Amendments (+ or -):..... | \$0.00 |
| | | | 3. CURRENT CONTRACT PRICE (Line 1 plus Line 2):..... | \$0.00 |
| | | | 4. Total completed and stored to date Column H on Progress Estimate:..... | \$0.00 |
| | | | 5. Retainage (per Agreement): | |
| | | | a. Work Completed - Column H (95% up to 50% of Contract or 2.5% of 100% of Contract) | \$0.00 |
| Total | \$0.00 | \$0.00 | 6. AMOUNT ELIGIBLE TO DATE (Line 4 minus 5)..... | \$0.00 |
| NET CHANGE BY CHANGE ORDERS: \$0.00 | | | 7. LESS PREVIOUS PAYMENTS (Line 6 from prior Application)..... | \$0.00 |
| | | | 8. AMOUNT DUE THIS APPLICATION (Line 6 minus Line 7)..... | \$0.00 |

CONTRACTOR'S CERTIFICATION

The undersigned Contractor certifies that:(1) all previous progress payments received from Owner on account of Work done under Contract have been applied on account to discharge Contractor's legitimate obligations incurred in connection with Work covered by prior Applications for Payment; (2) title of all Work, materials and equipment incorporated in said Work or otherwise listed in or covered by this Application for Payment will pass to Owner at time of payment free and clear of all Liens, security interests and encumbrances (except such as are covered by a Bond acceptable to Owner indemnifying Owner against any such Liens, security interest or encumbrances); and (3) all Work covered by the Application for Payment is in accordance with the Contract Documents and is not defective.

By: _____ Date: _____

Payment of: \$ _____
(Line 8 or other - attach explanation of other amount)

is recommended by: _____ (Contractor) _____ (Date)

Payment of: \$ _____
(Line 8 or other - attach explanation of other amount)

is recommended by: _____ (Owner) _____ (Date)

SECTION 00 65 16

CERTIFICATE OF SUBSTANTIAL COMPLETION

| | |
|-------------|-----------------------|
| Project: | |
| Owner: | Owner's Contract No.: |
| Contractor: | |

This [tentative] [definitive] Certificate of Substantial Completion applies to:

All Work under the Contract Documents: The following specified portions of the Work:

Date of Substantial Completion

The Work to which this Certificate applies has been inspected by authorized representatives of Contractor and Engineer, and found to be substantially complete. The Date of Substantial completion of the Project or portion thereof designated above is hereby declared and is also the date of commencement of applicable warranties required by the Contract Documents, except as stated below.

A [tentative] [definitive] list of items to be completed or corrected is attached hereto. This list may not be all-inclusive, and the failure to include any items on such list does not alter the responsibility of the Contractor to complete all Work in accordance with the Contract Documents.

The responsibilities between Owner and Contractor for security, operation, safety, maintenance, heat, utilities, insurance and warranties shall be as provided in the Contract Documents except as amended as follows:

Amended Responsibilities Not Amended

Owner's Amended Responsibilities:

Contractor's Amended Responsibilities:

The following documents are attached to and made part of this Certificate:

This Certificate does not constitute an acceptance of Work not in accordance with the Contract Documents nor is it a release of Contractor's obligation to complete the Work in accordance with the Contract Documents.

Executed by Engineer

Date

Accepted by Contractor

Date

SECTION 01 10 00

SUMMARY OF WORK

PART 1 – GENERAL

1.1 SUMMARY

- A. Section Includes
 - 1. References
 - 2. Work Covered by the Contract Documents
 - 3. Work Sequence/Schedule
 - 4. Use of Premises
 - 5. Warranty
 - 6. Miscellaneous Provisions

1.2 REFERENCES

- A. General Specifications. The work under this contract shall be in accordance with the City of De Pere, 2025 Construction Specifications and these Special Provisions and plans, and the latest edition of the Wisconsin Department of Transportation Standards Specifications for Highway and Structure Construction, where referenced in the City Specifications.
- B. Definitions. Any reference to the “state” or the “department” in said Standard Specifications shall mean the “City of De Pere” for the purposes of this contract.
- C. Industry Standards
 - 1. Unless the Contract Documents include more stringent requirements, applicable construction industry standards have the same force and effect as if bound or copied directly into the Contract Documents to the extent referenced. Such standards are made a part of the Contract Documents by reference.
 - 2. Comply with standards in effect as of date of the Contract Documents, unless otherwise indicated.
 - 3. If compliance with two or more standards is specified and the standards establish different or conflicting requirements for minimum quantities or quality levels, comply with the most stringent requirement.
 - 4. The quantity or quality level shown or specified shall be the minimum provided or performed. The actual installation may comply exactly with the minimum quantity or quality specified, or it may exceed the minimum within reasonable limits. To comply with these requirements, indicated numeric values are minimum or maximum, as appropriate, for the context of requirements.
 - 5. Each section of the specifications generally includes a list of reference standards normally referred to in that respective section. The purpose of this list is to furnish the Contractor with a list of standards normally used for outlining the quality control desired on the project.

The lists are not intended to be complete or all inclusive, but only a general reference of standards that are regularly referred to.

6. Each entity engaged in construction on the Project shall be familiar with industry standards applicable to its construction activity. Copies of applicable standards are not bound with the Contract Documents. Where copies of standards are needed to perform a required construction activity, obtain copies directly from the publication source and make them available on request.

1.3 WORK COVERED BY THE CONTRACT DOCUMENTS

A. Project Identification

1. Project Location
 - a. Community Center
600 Grant Street
De Pere, WI 54115
2. Work will be performed under the following prime contract:
 - a. Project 26-18 Community Center Air Handler Upgrade

B. The Work includes:

1. Demolition of existing supply fan.
2. Demolition of DX cooling coil and refrigerant lines.
3. Demolition of existing air-cooled condensing unit and concrete pad.
4. Installation of new air handler system including refrigerant lines, electrical, concrete pad and other associated appurtenances.

1.4 WORK SEQUENCE/SCHEDULE

- A. Project shall be completed by November 6, 2026. Work shall not begin until September 2, 2026 to prevent disruption to the Community center Cooling system over the hot weather months.
- B. Conduct construction activities to maintain access to business throughout construction. Access to premises shall not disturb business operation.
- C. All work is to be completed during normal building operation hours of Monday thru Thursday 7:30 AM to 5:00 PM and Friday 7:30AM to 11:30 AM.
- D. Coordinate all repairs with Maintenance Supervisor, Thomas Blohowiak at 920-639-1336.

1.5 USE OF PREMISES

- A. Contractor shall have full use of the premises for construction operations, including use of the Project Site, as allowed by law, ordinances, permits, easement agreements and the Contract documents.

SECTION 01 22 05

MEASUREMENT AND PAYMENT SPECIAL CONSTRUCTION

PART 1 – GENERAL

1.1 SUMMARY

- | | |
|---|---------------------|
| A. Section includes: | <u>Bid Item No.</u> |
| 1. Demolition of Existing Fixtures | SC-01 |
| 2. Installation of New Air Handler System | SC-02 |
- B. Unit Prices include:
1. Defined work for each Unit Price Item which will provide a functionally complete Project when combined with all unit price items. If there are specific work items which the Contractor believes are not identified in any Unit Price Item, but is required to provide a functionally complete Project, then the identified specific work items shall be included in the appropriate Unit Price Item.
 2. The method of measurement for payment.
 3. The price per unit for payment.

1.2 GENERAL WORK ITEMS

- A. Include with the appropriate Unit Price Item the following work items which are common to the Unit Price Items for special construction.
- B. If there is a specific Unit Price Item for any of the following items, then the work item shall be included with that specific unit price item.
1. Loading, hauling and disposing of surplus material.
 2. Maintenance, protection, replacement and/or repair of facilities not designated for alteration on the Site beyond the limits identified.
 3. Protection of work area.
 4. Clean work area after completion.
 5. Dust control.
 6. Regulatory requirements.
 7. Quality assurance and quality control testing and inspections.
 8. Shop drawings and other submittals.

1.3 Demolition of Existing Fixtures

- A. The unit price for Demolition of Existing Fixtures work includes:
1. General Work Items of Article 1.2.
 2. Removal of supply fan from existing air-handling unit. Preparation of the area for new fan array implementation per plans and specifications.

3. Removal of DX cooling coil from existing air-handling unit. Removal of two (2) 2-1/8" refrigerant suction lines and two (2) 5/8" refrigerant liquid lines per plans and specifications.
4. Removal of existing air-cooled condensing unit, concrete pad, asphalt pavement, and concrete sidewalk per plans and specifications.
5. Asbestos abatement per plans and specifications.

B. Measurement of payment will not be made.

C. The unit of measurement for payment is lump sum.

1.4 Installation of New Air Handler System

A. The unit price for New Air Handler System work includes:

1. General Work Items of Article 1.2.
2. Install new chilled water-cooling coil including associated appurtenances and seal coil to interior face of air handling unit per plans and specifications.
3. Install new air-cooled chiller including associated appurtenances exterior on grade.
4. Install new chilled water air control and pumping piping including associated appurtenances with sizes as indicated on the plan.
5. Provide new fan array including associated appurtenances for existing air handling unit.
6. Provide new 6" concrete pad, asphalt pavement restoration, and sidewalk restoration per plans and specifications.
7. Restore disturbed areas adjacent to pad with asphalt and/or concrete restoration
8. Provide line voltage power wiring, motor starters, and disconnects per plans and specifications.
9. Provide access panels to provide access to HVAC system components per plans and specifications.

B. Measurement of payment will not be made.

C. The unit of measurement for payment is lump sum.

END OF SECTION

SECTION 01 29 00

PAYMENT PROCEDURES

PART 1 – GENERAL

1.1 SUMMARY

A. This section includes:

1. Administrative and procedural requirements necessary to prepare and process Applications for Payment.

1.2 SCHEDULE OF VALUES

- A. Unit Price work will be the Schedule of Values used as the basis for reviewing Applications for Payment.

1.3 APPLICATIONS FOR PAYMENT

- A. Each Application for Payment shall be consistent with previous applications and payments as recommended by the Engineer and approved by Owner.
- B. The date for each progress payment should be the 3rd Wednesday of each month. The period covered by each Application for Payment starts on the day following the end of the preceding period and ends the 4th Friday of the Month.
- C. Use forms provided by Engineer for Applications for Payment. Sample copy of the Application for Payment and Continuation Sheet is included in Section 00 62 76.
- D. Application Preparation Procedures
1. When requested by the Contractor, the Engineer will determine the actual quantities and classifications of Unit Price Work performed.
 - a. Preliminary determinations will be reviewed with the Contractor before completing Application for Payment.
 - b. Engineer will complete the Application for Payment based on Engineer's decision on actual quantities and classifications.
 - c. Engineer will submit three original copies of Application for Payment to Contractor for certification of all three original copies.
 - d. Contractor shall submit signed Application for Payment to Owner for approval within time frame agreed to at the Preconstruction Conference.
 2. If payment is requested for materials and equipment not incorporated in the Work, then the following shall be submitted with the Application for Payment:
 - a. Evidence that materials and equipment are suitably stored at the site or at another location agreed to in writing.

- b. A bill of sale, invoice, or other documentation warranting that the materials and equipment are free and clear of all liens.
 - c. Evidence that the materials and equipment are covered by property insurance.
 3. Complete every entry on form. Execute by a person authorized to sign legal documents on behalf of Contractor.
- E. With each Application for Payment, submit waivers of liens from subcontractors and suppliers for the construction period covered by the previous application.
1. Submit partial waivers on each item for amount requested before deduction for retainage on each item.
 2. When an application shows completion for an item, submit final or full waivers.
 3. Owner reserves the right to designate which entities involved in the Work shall submit waivers.
 4. Submit final Application for Payment with or preceded by final waivers from every entity involved with performance of the Work covered by the application.
 5. Submit waivers of lien on forms executed in a manner acceptable to Owner.
- F. The following administrative actions and submittals shall precede or coincide with submittal of first Application for Payment:
1. List of subcontractors.
 2. Schedule of Values (For Lump Sum Work).
 3. Contractor's construction schedule.
- G. Submit final Application for Payment with releases and supporting documentation not previously submitted and accepted including, but not limited, to the following:
1. Evidence of completion of Project closeout requirements.
 2. Insurance certificates for products and completed operations where required and proof that taxes, fees, and similar obligations were paid.
 3. Updated final statement, accounting for final changes to the Contract Sum.
 4. Consent of Surety to Final Payment.
 5. Final lien waivers as evidence that claims have been settled.
 6. Final liquidated damages settlement statement.

PART 2 – PRODUCTS

PART 3 – EXECUTION

END OF SECTION

SECTION 01 33 00

SUBMITTALS

PART 1 – GENERAL

1.1 SUMMARY

- A. Section includes administrative and procedural requirements for submittals:
 - 1. Progress Schedule.
 - 2. Schedule of Shop Drawings and Sample Submittals.
 - 3. Shop Drawings.
- B. Failure to meet Submittal requirements to the satisfaction of the Engineer will constitute unsatisfactory performance of the work in accordance with the Contract Documents, therefore, the Engineer may recommend to the Owner that all or a portion of payments requested during the corresponding pay period be withheld until these requirements are met.

1.2 SUBMITTAL PROCEDURES

- A. Coordination: Transmit each submittal sufficiently in advance of performance of related construction activities to avoid delay.
 - 1. Coordinate each submittal with fabrication, purchasing, testing, delivery, other submittals, and related activities that require sequential activity.
 - 2. Coordinate transmittal of different types of submittals for related elements of the work so processing will not be delayed by the need to review submittals concurrently for coordination.
 - a. The Engineer reserves the right to withhold action on a submittal requiring coordination with other submittals until all related submittals are received.
 - 3. To avoid the need to delay installation as a result of the time required to process submittals, allow sufficient time for submittal review, including time for re-submittals.
 - a. Allow two weeks for initial submittal.
 - b. Allow two weeks for reprocessing each submittal.
 - c. No extension of Contract Time will be authorized because of failure to transmit submittals to the Engineer sufficiently in advance of the work to permit processing.
- B. Submittal Preparation: Place a permanent label or title block on each submittal for identification. Indicate the name of the entity that prepared each submittal on the label or title block.
 - 1. Assign a reference number to each submittal and re-submittal.
 - 2. Provide a space approximately four (4) by five (5) inches (100 by 125 mm) on the label or beside the title block on Shop Drawings to record the Contractor's review and approval markings and the action taken.
 - 3. Include the following information on the label for processing and recording action taken.

- a. Project name.
 - b. Date.
 - c. Name and address of the Engineer.
 - d. Name and address of the Contractor.
 - e. Name and address of the subcontractor.
 - f. Name and address of the supplier.
 - g. Name of the manufacturer.
 - h. Number and title of appropriate Specification Section.
 - i. Drawing number and detail references, as appropriate.
4. Each submittal shall be stamped by the Contractor indicating that submittal was reviewed for conformance with the Contract Documents. The Engineer will not accept unstamped submittals.
- C. Submittal Transmittal: Package each submittal appropriately for transmittal and handling. Transmit each submittal to the Engineer. The Engineer will not accept submittals received from sources other than the Contractor.
1. On the transmittal, record relevant information and requests for Engineer action. On a form, or separate sheet, record deviations from Contract Document requirements, including variations, limitations, and justifications. Include Contractor's certification that information complies with Contract Document requirements.

1.3 CONTRACTOR'S PROGRESS SCHEDULE

- A. Prepare and submit to the Engineer within 10 (ten) days after the Effective Date of the Agreement, four copies of a preliminary progress schedule of the work activities from Notice to Proceed until Substantial Completion.
1. Provide sufficient detail of the work activities comprising the schedule to assure adequate planning and execution of the work, such that in the judgment of the Engineer, it provides an appropriate basis for monitoring and evaluation of the progress of the work. A work activity is defined as an activity which requires substantial time and resources (manpower, equipment, and/or material) to complete and must be performed before the contract is considered complete.
 2. The schedule shall indicate the sequence of work activities. Identify each activity with a description, start date, completion date and duration. Include, but do not limit to the following items, as appropriate to this contract:
 - a. Shop drawing review by the Engineer.
 - b. Excavation and grading.
 - c. Asphalt and concrete placement sequence.
 - d. Restoration.
 - e. Construction of various segments of utilities.
 - f. Subcontractor's items of work.
 - g. Allowance for inclement weather.
 - h. Contract interfaces, date of Substantial Completion.
 - i. Interfacing and sequencing with existing facilities and utilities.

- j. Sequencing of major construction activities.
 - k. Milestones and completion dates.
- B. Distribution: Following response to the initial submittal, print and distribute copies of the revised construction schedule to the Engineer, Subcontractors, and other parties required to comply with scheduled dates. When revisions are made, distribute to the same parties. Delete parties from distribution when they have completed their assigned portion of the work and are no longer involved in construction activities.
- C. Schedule Updating: Revise the schedule after each meeting, event, or activity where revisions have been recognized or made. Issue the updated schedule concurrently with the report of each meeting.
- D. Punch List: Prepare and submit to the Engineer within ten (10) days after substantial completion a detailed progress schedule for outstanding work and punch list items.

1.4 SCHEDULE OF SHOP DRAWINGS AND SAMPLE SUBMITTALS

- A. Submit electronic or one (1) hard copy of preliminary submittal schedule in accordance with the General Conditions of the Contract and as follows:
- 1. Coordinate submittal schedule with the subcontractors, Schedule of Values, and of products as well as the Contractor's Progress Schedule.
 - 2. Prepare the schedule in chronological order. Provide the following information:
 - a. Scheduled date for the first submittal.
 - b. Related Section number.
 - c. Submittal category (Shop Drawings, Product Data, or Samples).
 - d. Name of the subcontractor.
 - e. Description of the part of the work covered.
 - f. Scheduled date for the Engineer's final release or approval.
- B. Distribution: Following response to the initial submittal, print and distribute copies of the revised construction schedule to the Engineer, Subcontractors, and other parties required to comply with scheduled dates. Post copies in the field office. When revisions are made, distribute to the same parties. Delete parties from distribution when they have completed their assigned portion of the work and are no longer involved in construction activities.
- C. Schedule Updating: Revise the schedule after each meeting or activity where revisions have been recognized or made. Issue the updated schedule concurrently with the report of each meeting.

1.5 SHOP DRAWINGS

- A. Submit newly prepared information drawn accurately to scale. Highlight, encircle, or otherwise indicate deviations from the Contract Documents. Do not reproduce Contract Documents or

copy standard information as the basis of Shop Drawings. Standard information prepared without specific reference to the Project is not a Shop Drawing.

- B. Collect product data into a single submittal for each element of construction of system. Product data includes printed information, such as manufacturer's installation instructions, catalog cuts, standard color charts, roughing-in diagrams and templates, standard wiring diagrams, and performance curves.
 - 1. Mark each copy to show actual product to be provided. Where printed Product Data includes information on several products that are not required, mark copies to indicate the applicable information. Include the following information:
 - a. Manufacturer's printed recommendations.
 - b. Compliance with trade association standards.
 - c. Compliance with recognized testing agency standards.
 - d. Application of testing agency labels and seals.
 - e. Notation of dimensions verified by field measurement.
 - f. Notation of coordination requirements.
- C. Do not use shop drawings without an appropriate final stamp indicating action taken.
- D. Submittals: Submit electronic or one (1) hard copy of each required submittal. The Engineer will scan and return the submittal to the Contractor marked with action taken and corrections or modifications required.
- E. Distribution: Furnish copies of reviewed submittal to installers, subcontractors, suppliers, manufacturers, fabricators, and others required for performance of construction activities. Show distribution on transmittal forms. Maintain one copy at the project site for reference.
 - 1. Do not proceed with installation until a copy of the Shop drawing is in the Installer's possession.
 - 2. Do not permit use of unmarked copies of the Shop Drawing in connection with construction.

1.6 ENGINEER'S ACTION

- A. Except for submittals for the record or information, where action and return is required, the Engineer will review each submittal, mark to indicate action taken, and return promptly. The Engineer will stamp each submittal with a uniform action stamp. The Engineer will mark the stamp appropriately to indicate the action taken, as follows:
 - 1. "No Exceptions Taken": The work covered by the submittal may proceed provided it complies with notations or corrections on the submittal and requirements of the Contract Documents.
 - 2. "Make Corrections Noted": The work covered by the submittal may proceed provided it complies with notations or corrections on the submittal and requirements of the Contract Documents.

3. "Amend and Resubmit": Do not proceed with work covered by the submittal. Resubmit without delay. Do not use, or allow others to use, submittals marked "Amend and Resubmit" at the Project Site or elsewhere where work is in progress.
 4. "Rejected – See Remarks": Do not proceed with work covered by the submittal. Resubmit without delay. Do not use, or allow others to use, submittals marked "Rejected and Resubmit" at the Project Site or elsewhere where work is in progress.
- B. Unsolicited Submittals: The Engineer will return unsolicited submittals to the sender without action.

PART 2 – PRODUCTS

PART 3 – EXECUTION

END OF SECTION

EXHIBIT A

HVAC MASTER SPECIFICATIONS

HVAC
MASTER SPECIFICATIONS
Short Form - Plan Note Format



General:

Project shall be site visited to verify actual conditions. All work shall comply with all applicable State and Local Codes and Regulations.

Mechanical contractor shall provide as-built drawings, HVAC system operation and maintenance manuals and training to the owner's maintenance personnel.

The temperature control system shall be tested, adjusted and calibrated in compliance with SPS 364.0313. Air and hydronic systems shall be balanced in accordance with the National Environmental Balancing Bureau (NEBB), and SPS 364.0313. Submit (1) one electronic copy of air balancing reports. Submit (1) one electronic copy of shop drawings for approval and (1) one electronic copy of operation & maintenance manuals for all equipment.

Firestopping shall be provided as required to maintain the fire resistance rating of the walls and floors penetrated by the HVAC system components. Firestopping shall meet ASTM E814 requirements.

Concrete pads will be provided for all HVAC equipment that is floor supported, unless otherwise specifically noted.

Rooms with specific pressure relationship requirements such as laboratories, operating rooms and isolation rooms shall have all wall piping and ductwork penetrations sealed.

Work by Others:

The following work is not provided by the Mechanical Contractor:

Asbestos abatement.

Line voltage power wiring, motor starters, and disconnects, unless otherwise specifically noted. Access panels in the general construction to provide service access to HVAC system components.

Painting of HVAC systems, unless otherwise specifically noted.

Exterior concrete pads for support of equipment on grade, or for anchoring of underground tanks. Structural steel for support of roof mounted HVAC equipment, including miscellaneous steel for roof opening framing. Pouring concrete pads for all floor supported HVAC equipment unless otherwise specifically noted. Structural steel for floor support of HVAC equipment shall be provided by the mechanical contractor, unless otherwise specifically noted.

Fire suppression systems for any and all kitchen exhaust hoods unless otherwise specifically stated.

Electrical work associated with mechanical equipment replacements and additions shall be provided by the electrical contractor, including but not limited to: field verification of existing electrical service conditions prior to commencing work; modification or resizing of existing branch circuits, disconnects, overcurrent protection, and motor starters to match nameplate requirements

HVAC
MASTER SPECIFICATIONS
Short Form - Plan Note Format



of the replacement equipment; and provision of new power, wiring, conduit, disconnects, and overcurrent protection for the new equipment. The electrical contractor shall coordinate final equipment electrical data with the mechanical contractor prior to rough-in and report any discrepancies between existing conditions and contract documents to the engineer of record before proceeding.

Identification For HVAC Piping and Equipment:

Coordinate installation of identifying devices with completion of covering and painting of surfaces where devices are to be applied. Coordinate installation of identifying devices with locations of access panels and doors.

Equipment Labels

Provide adhesive labels for mechanical identification. Black letter color on yellow background. Minimum label size shall not be less than 2 inches. Minimum letter size shall not be less than 1 inch.

Install or permanently fasten labels on each major item of mechanical equipment and locate equipment labels where accessible and visible

Pipe Labels

Preprinted, color-coded, with lettering indicating service, and showing flow direction. Self-adhesive type, printed plastic with contact-type, permanent-adhesive backing.

Include identification of piping service using same designations or abbreviations as used on the drawings and include an arrow indicating flow direction. Lettering size shall be at least 1-1/2 inches high. Flow direction arrows can be separated from the pipe identification label to indicate flow direction.

Locate pipe labels where piping is exposed or above accessible ceilings in finished spaces; machine rooms; accessible maintenance spaces such as shafts, tunnels, and plenums; and exterior exposed locations as follows:

- At least once in each room.
- Near each valve and control device.
- Near each branch connection, excluding short takeoffs for fixtures and terminal units. Where flow pattern is not obvious, mark each pipe at branch.
- Near penetrations through walls, floors, ceilings, and inaccessible enclosures.
- At access doors, manholes, and similar access points that permit view of concealed piping.
- Near to major equipment items and other points of origination and termination.
- Spaced at maximum intervals of 20 feet along each run. Reduce intervals to 10 feet in areas of congested piping and equipment.

Valve Tags

Stamped or engraved with 1/4-inch letters for piping system abbreviation and 1/2-inch numbers. Tag material shall be brass, 0.032-inch minimum thickness with predrilled or stamped holes for

HVAC
MASTER SPECIFICATIONS
Short Form - Plan Note Format



attachment hardware. Fasteners shall be brass wire-link or beaded chain; or S-hook.

Install tags on valves and control devices in piping systems, except check valves; valves within factory-fabricated equipment units; shutoff valves; and HVAC terminal devices and similar roughing-in connections of end-use fixtures and units. List tagged valves in a valve schedule.

Valve Schedules

For each piping system, on 8-1/2-by-11-inch bond paper. Tabulate valve number, piping system, system abbreviation (as shown on valve tag), location of valve (room or space), normal-operating position (open, closed, or modulating), and variations for identification. Mark valves for emergency shutoff and similar special uses. Valve schedule shall be included in operation and maintenance data.

Pipe and Fittings

General:

Piping shall be reamed and thoroughly cleaned of scale and dirt before being installed. Provide vents at all high piping points and drains with hose connection at low points. Provide Nibco LD2000 butterfly valves, ANSI 200, with buna seat, stainless steel shaft and disc and multi-position handle. Ball valves shall be full port Nibco type S-585.

Piping Construction and Insulation:

Refer to the standard piping matrix on the plan documents.

Fiberglass insulation shall be 3 lbs./cu.ft. density, ANSI/ASTM C547 'k' value of 0.24 at 75 deg. F mean temperature, with a flame spread rating of 25 or less and a smoke developed rating 50 or less. Provide white kraft faced piping jacket with self-sealing lap. Provide Zeston pre-molded PVC insulation fittings for all piping fittings. Label piping to identify the heating or cooling system, with flow directional arrows.

Variable Frequency Drives

Provide ABB ACH550 or approved equal, variable frequency drives with drive bypass controller. Drive shall be UL listed, fully digital PWM design with diode front end and IGBT transistorized output. Provide drive with a NEMA 1 enclosure, circuit breaker type disconnect switch, BACnet interface board, front panel digital keypad programming, with Hand-Off-Auto selections and manual speed control. The drive shall have preprogrammed protection for over current, short circuit, over voltage, under voltage, loss of analog input, motor overload and inverter overload. Provide 36-month parts and labor warranty from date of shipment. Provide VFD start-up from factory authorized technician. Provide (1) electronic copy of the VFD start-up report.

Packaged Air-Cooled Water Chillers

Provide air-cooled water chillers as scheduled on the drawings. Provide chillers with a one-year, full unit warranty. Provide chiller factory start-up with a start-up report.

Acceptable manufacturers: Carrier, Daikin, Trane and York.

Provide a factory assembled and tested packaged air-cooled water chiller complete with hermetic

HVAC
MASTER SPECIFICATIONS
Short Form - Plan Note Format



compressors, air cooled condensers, evaporator, flow switch, refrigeration controls and control panel. Unit selection shall be based on a glycol/water solution as indicated on the plan schedules. Unit efficiency ratings shall be not less than the ASHRAE 90.1 efficiency ratings. Construction and rating shall be in accordance with ARI 550.

Insulate evaporator and refrigeration piping to prevent condensation. Provide heat tape with thermostat to protect the evaporator from freezing down to an ambient temperature of -20 deg. F for chillers that do not utilize glycol for freeze protection. Provide chiller with single point electrical power connection, and prewired unit mounted disconnect switch. Condenser shall be constructed with aluminum fins mechanically secured to copper tubing. Provide microprocessor control with digital programming to determine chiller function, start/stop and alarms and BACnet communication interface.

Inline Pumps

Furnish and install inline pumps as shown on the plans.

Acceptable manufacturers: Bell & Gossett, Taco, or Armstrong.

The pumps shall be close-coupled, inline for vertical or horizontal installation, in cast iron bronze fitted (or all bronze) construction specifically designed for quiet operation. Suitable standard operations at 250°F and 175 PSIG working pressure. The pump internals shall be capable of being serviced without disturbing piping connections.

The motor bearings shall support the shaft via heavy-duty permanently lubricated ball bearings.

The pump motor shall be a single speed motor with permanently lubricated or grease-lubricated ball bearings with adjustable alignment. Motors shall be non-overloading at any point on the pump curve and shall meet NEMA specifications.

The pump shall be factory assembled and tested, thoroughly cleaned, and painted with one coat of machinery enamel prior to shipment. A set of installation instructions shall be included with the pump. Pumps shall be installed in accordance with the manufacturer's instructions.

Provide pressure gauges piped and valved for measuring both suction and discharge pressure, complete with shutoff gauge valves.

Furnish and install triple duty valves on the discharge side of all pumps and furnish and install a line size shut-off valve on the suction side of all pumps

Reduction from line size to pump connection size shall be made with eccentric reducers attached to the pump with tops flat to allow continuity of flow.

Provide an adequate number of isolation valves for service and maintenance of the system and its components.

HVAC
MASTER SPECIFICATIONS
Short Form - Plan Note Format



Power wiring, as required, shall be the responsibility of the electrical contractor. All wiring shall be performed per manufacturer's instruction and applicable state, federal, and local codes.

Control wiring for remote mounted switches and sensor / transmitters shall be the responsibility of the control's contractor. All wiring shall be performed per manufacturer's instructions and applicable state, federal, and local codes.

Air Control

Air separator shall be installed in return piping and shall be Bell and Gossett, Rolairtrol for piping sizes larger than 2", and in-line Airtrol fittings for piping sizes 2" and under. The unit shall be constructed for 125 PSI working pressure and stamped with the ASME "U" symbol. The removable galvanized system strainer shall be 3/16" diameter perforations and a free area of not less than five times the area of the connecting pipe. The Contractor shall remove and clean the strainer after the initial cleaning and again in 30 days. A blowdown connection shall be provided to facilitate routine cleaning.

Pipe air outlet to compression tank, pitching up to tank. Connect air control line to tanks using Bell and Gossett "Airtrol" tank fittings. The tank fitting shall include a manual vent.

Expansion Tanks

Tanks shall be constructed according to requirements of ASME for 125 PSI service. Securely support tanks in place where shown.

Provide Bell & Gossett "Airtrol" tank fittings, air charging drain valve and gauge glasses on tank.

Expansion tanks shall be diaphragm, bladder or standard compression type tanks as scheduled.

Glycol Fill Stations

The hydronic system feeder shall be Axiom Industries LTD. Model DMF300. System shall include: 17 US gallon storage/mixing tank with cover; pump suction hose with inlet strainer; pressure pump with thermal cutout; integral pressure switch; integral check valve; cord and plug; pre-charged accumulator tank with EPDM diaphragm; manual diverter valve for purging air and agitating elements of storage tank; pressure regulating valve complete with pressure gauge; built in check valve; union connection; 1/2" x 36" long flexible hose with check valve; low level pump cutout.

Pressure pump shall be capable of running dry without damage. Power supply 115/60/1 0.7A. Unit shall be completely pre-assembled and certified by recognized testing agency to CSA standard C22.2 No 68.

Additional low level alarm panel to be provided with the hydronic system feeder. The low-level alarm panel shall provide a selectable audible alarm and additional remote monitoring dry contacts.

AHU Cooling Coils

The unit cooling coils shall be equal to sizes and capacities scheduled. Mount coils in the casing

HVAC
MASTER SPECIFICATIONS
Short Form - Plan Note Format



to be accessible for service and to be removable from the side of the unit. Coil U-bends shall be within the unit insulated casing. Support coils along their entire length within the casing and pitch for proper drainage.

Limit coil face velocity to 500 feet per minute, or otherwise as required to prevent moisture carryover.

Construct evaporator coils with copper tubes and aluminum fins. Fins shall be mechanically bonded to the tubes. Coils shall be intertwined type for units with multiple refrigerant circuits. Face split coils are not acceptable.

Cooling coil drain pan shall be stainless steel pitched to a drain connection.

Include control components required for proper operation of units and auxiliary equipment located within the unit. Include the following:

- 24 VAC output, factory-installed and wired control transformer for internal control power requirements
- Relays as required to achieve specified operation
- Non-fused, weatherproof, prewired disconnect switch
- Provide units with one extra set of fan belts and one extra set of control fuses.

Temperature Controls

Provide Tridium, Johnson Controls, Siemens, Automated Logic or Delta direct digital control (DDC) system consisting of thermostats, sensors, control valves and damper operators, operators, interface equipment and other electronic equipment to complete the control functions, as specified. Coordinate type of space temperature sensor control function with the owner.

Provide DDC control operating information consisting of system control drawings, wiring diagrams, detailed sequence of HVAC component system operation, summary listing of DDC control points, engineering data for each control system component with size and selection. Submit one electronic copy of DDC submittals for approval.

Automatic temperature control valves and automatic dampers shall be provided by the Temperature Control Contractor. Provide control valves and damper actuators. Cooling 3-way control valves shall be normally open with a 1.2 minimum Cv rating.

All low voltage wiring shall be plenum rated thermostat wire. All line voltage wiring required to complete the DDC control system, such as electrical interlocks, shall be run in thin wall conduit.

All setpoints defined within the sequence of operations shall be fully adjustable via the BAS system user interface.

Execution

This Contractor shall do all cutting necessary for the passage of pipe. This Contractor shall take

**HVAC
MASTER SPECIFICATIONS
Short Form - Plan Note Format**



all necessary precautions to protect his work from damage or injury until the completion and final acceptance of his work.

This HVAC Contractor must instruct the Owner and his representatives in the proper operating techniques of the system. The Contractor shall provide Owner with Operating & Maintenance Manuals.

The Contractor must install piping, ductwork and equipment to prevent transmission of noise.

The Heating Contractor shall guarantee the entire system against all defects for a period of one (1) year from date of final acceptance.

EXHIBIT B

AIR HANDLER UNIT (AHU) UPGRADE PLANS

DE PERE COMMUNITY CENTER

AHU UPGRADE

600 GRANT STREET, DE PERE, WI 54115

ISSUANCE HISTORY

BID DOCUMENTS 11/17/25

SHEET REVISIONS

TITLE TITLE PAGE

JOB#: 7735
 DRAWN BY: MRL
 CHECKED BY: WPH
 SCALE: AS SHOWN

M000

DUCT SEALING (IECC 403.12.1)

SEAL DUCTWORK IN ACCORDANCE WITH SMACNA HVAC DUCT CONSTRUCTION STANDARDS, TABLE 1-1, SEAL CLASS A.

ALL JOINTS, LONGITUDINAL AND TRANSVERSE SEAMS AND CONNECTIONS IN DUCTWORK SHALL BE SECURELY FASTENED AND SEALED WITH WELDS, GASKETS, MASTICS (ADHESIVES), MASTIC-PLUS-EMBEDDED-FABRIC SYSTEMS OR TAPE. TAPES AND MASTICS USED TO SEAL DUCTWORK SHALL BE LISTED AND LABELED IN ACCORDANCE WITH UL 181.

| LABELING FOR APPROVED TAPES AND MASTICS | |
|---|------------|
| SEALANT | UL LISTING |
| DUCTWORK | |
| PRESSURE-SENSITIVE TAPE | 181A-P |
| MASTIC | 181A-M |
| HEAT-SENSITIVE TAPE | 181A-H |
| FLEXIBLE AIR DUCTS AND FLEXIBLE AIR CONNECTORS | |
| PRESSURE-SENSITIVE TAPE | 181B-FX |
| MASTIC | 181B-M |

DUCT CONNECTIONS TO FLANGES OF AIR DISTRIBUTION SYSTEM EQUIPMENT SHALL BE SEALED AND MECHANICALLY FASTENED.

MECHANICAL FASTENERS FOR USE WITH FLEXIBLE NON-METALLIC AIR DUCTS SHALL COMPLY WITH UL 181B AND SHALL BE MARKED 181B-C.

UNLISTED DUCT TAPE IS NOT PERMITTED AS A SEALANT ON ANY DUCT.

NOTE:
 TAPE ALONE CANNOT BE SUBSTITUTED FOR MECHANICAL FASTENERS.

| MECHANICAL SHEET LIST | |
|-----------------------|---|
| SHEET NUMBER | SHEET NAME |
| M000 | TITLE PAGE |
| M101 | FIRST FLOOR DEMO PLAN |
| M301 | FIRST FLOOR MECHANICAL PLAN |
| M601 | HVAC DETAILS & SCHEDULES |
| M901 | HVAC SPECIFICATIONS & CONTROL SEQUENCES |

APPLICABLE CODES AND REGULATIONS:

THE DRAWINGS HAVE BEEN PREPARED IN ACCORDANCE WITH THE FOLLOWING CODES - NOTIFY THE ENGINEER OF ANY CONFLICTS.

STATE OF WISCONSIN CH. SPS 341 - BOILER AND PRESSURE VESSELS CODE
 STATE OF WISCONSIN CH. SPS 345 - MECHANICAL REFRIGERATION CODE
 STATE OF WISCONSIN CH. SPS 362 - BUILDINGS AND STRUCTURES CODE, ADOPTS THE INTERNATIONAL BUILDING CODE - 2021 VERSION (WITH AMENDMENTS)
 STATE OF WISCONSIN CH. SPS 363 - ENERGY CONSERVATION CODE, ADOPTS THE INTERNATIONAL ENERGY CONSERVATION CODE - 2021 VERSION (WITH AMENDMENTS)
 STATE OF WISCONSIN CH. SPS 364 - HEATING, VENTILATING AND AIR CONDITIONING CODE, ADOPTS THE INTERNATIONAL MECHANICAL CODE - 2021 VERSION (WITH AMENDMENTS)
 STATE OF WISCONSIN CH. SPS 365 - FUEL GAS APPLIANCES CODE, ADOPTS THE INTERNATIONAL FUEL GAS CODE - 2021 VERSION (WITH AMENDMENTS)
 STATE OF WISCONSIN CH. SPS 366 - EXISTING BUILDINGS CODE, ADOPTS THE INTERNATIONAL EXISTING BUILDING CODE - 2021 VERSION (WITH AMENDMENTS)
 NATIONAL FIRE PROTECTION ASSOCIATION CH. 54 - REGARDING GAS PIPING INSTALLATION (AS ADOPTED BY SPS 365)
 SHEET METAL AND AIR CONDITIONING CONTRACTORS NATIONAL ASSOCIATED INC. (SMACNA) STANDARDS

GENERAL NOTES:

- THESE GENERAL DRAWING NOTES APPLY TO THE SCOPE OF WORK AND SHALL BE CONSIDERED THE DEFAULT REQUIREMENTS UNLESS INFORMATION IS SPECIFICALLY NOTED ELSEWHERE ON THE PLAN DOCUMENTS.
- FIELD VERIFY EXISTING CONDITIONS PRIOR TO FABRICATION OF SYSTEMS AND INSTALLATION OF WORK.
- ALL HVAC WORK SHALL BE COORDINATED WITH THE WORK OF OTHER TRADES.
- ALL DUCTWORK SHALL BE CONSTRUCTED AND INSTALLED IN ACCORDANCE WITH SMACNA STANDARDS.
- ALL DUCTWORK SHALL BE SHEETMETAL EXCEPT FOR ROUND BRANCH DUCT RUN-OUTS FOR FINAL DIFFUSER CONNECTIONS, WHICH SHALL BE FLEXIBLE DUCTWORK. MAXIMUM FLEXIBLE DUCT LENGTH ALLOWED IS 6 FEET.
- ACCESS PANELS FOR ACCESS TO HVAC SYSTEMS WILL BE COORDINATED WITH OTHER TRADES OF WORK PROVIDING ACCESS PANELS.
- ALL PIPING AND DUCTWORK PENETRATIONS THROUGH WALLS, FLOORS, OR PARTITIONS IDENTIFIED AS FIRE WALLS, SMOKE TIGHT WALLS, FIRE BARRIERS, SMOKE BARRIERS, SHAFTS, OR OTHER FIRE RATED CONSTRUCTION SHALL BE FIRE STOPPED AND/OR PROTECTED WITH REQUIRED LIFE SAFETY DAMPERS TO MAINTAIN FIRE RATINGS, SMOKE RATINGS, AND UL LISTINGS.
- ALL COOLING COIL CONDENSATE DRAIN PIPING SHALL BE PITCHED AT 1/8" PER FOOT IN THE DIRECTION OF FLOW DOWN TO DRAIN RECEPTORS.
- THERMOSTATS THAT HAVE USER ADJUSTABLE SETPOINTS SHALL BE INSTALLED 48" ABOVE FINISHED FLOOR. COORDINATE ALL THERMOSTAT LOCATIONS WITH THE PROJECT ARCHITECT BEFORE INSTALLATION. WHEN THERMOSTATS ARE NOT INDICATED ON THE PLANS, COORDINATE WITH THE ENGINEER PRIOR TO INSTALLATION.
- FINAL TESTING, ADJUSTING AND BALANCING (TAB) WORK WILL BE PROVIDED IN ACCORDANCE WITH ASSOCIATED AIR BALANCE COUNCIL (AABC) OR NATIONAL ENVIRONMENTAL BALANCING BUREAU (NEBB) REQUIREMENTS. SYSTEMS SHALL BE BALANCED TO WITHIN +/-10% OF AIR AND WATER QUANTITIES AS INDICATED ON PLANS AND SCHEDULES. 3 SETS OF TAB REPORTS SHALL BE PROVIDED TO THE OWNER IN A FORMAT ACCEPTABLE TO THE OWNER, OR AS OTHERWISE REQUIRED PER CONTRACT REQUIREMENTS. RETAIN A COPY OF THE TAB REPORT AT THE PROJECT SITE FOR REVIEW BY THE LOCAL AHJ.
- ALL OPENINGS IN EXISTING GENERAL CONSTRUCTION FOR NEW HVAC WORK WILL BE PROVIDED BY THE MECHANICAL CONTRACTOR, UNLESS NOTED OTHERWISE.

HVAC LEGEND

| SYMBOL | IDENTIFICATION | SYMBOL | IDENTIFICATION |
|--------|-------------------------------------|--------|----------------------------------|
| | SUPPLY AIR DUCT UP | | SUPPLY AIR DUCT DOWN |
| | RETURN OR OUTSIDE AIR DUCT UP | | RETURN OR OUTSIDE AIR DUCT DOWN |
| | EXHAUST AIR DUCT UP | | EXHAUST AIR DUCT DOWN |
| | FIRE DAMPER | | SMOKE DAMPER |
| | FIRE SMOKE DAMPER | | VOLUME DAMPER |
| | AIR FLOW ARROW | | DUCT TRANSITION |
| | DUCT MOUNTED SMOKE DETECTOR | | MOTORIZED DAMPER |
| | REFRIGERANT SENSOR | | THERMOSTAT |
| | CO2 SENSOR | | HUMIDISTAT |
| | ROUND DUCT / PIPE ELBOW DOWN | | ROUND DUCT / PIPE UP |
| | UNION | | END CAP |
| | BUTTERFLY VALVE | | CONSTANT FLOW REGULATING VALVE |
| | 2-WAY CONTROL VALVE, MODULATING | | 3-WAY CONTROL VALVE, MODULATING |
| | GAS VALVE | | BALL VALVE |
| | STEAM TRAP | | GATE VALVE |
| | CHECK VALVE | | STRAINER |
| | ANGLE VALVE | | RELIEF VALVE |
| | DOUBLE CHECK VALVE | | TRIPLE DUTY VALVE |
| | GLOBE VALVE | | FLOW SWITCH |
| | FLEXIBLE CONNECTION | | PRESSURE GAUGE |
| | THERMOMETER | | PIPE FLOW DIRECTION ARROW |
| | IN LINE PIPE DROP | | PIPE ELBOW UP TAKE OFF |
| | PIPE ELBOW DOWN | | PIPE ELBOW UP |
| | CITY WATER | | CIRCULATING PUMP |
| | NATURAL GAS | | DRAIN |
| | PROPANE GAS | | PUMP CONDENSATE |
| | LOW TEMPERATURE HOT WATER SUPPLY | | CONDENSATE DRAIN |
| | CHILLED WATER SUPPLY | | LOW TEMPERATURE HOT WATER RETURN |
| | HIGH PRESSURE STEAM | | CHILLED WATER RETURN |
| | LOW PRESSURE STEAM | | HIGH PRESSURE CONDENSATE |
| | CONDENSER WATER SUPPLY | | LOW PRESSURE CONDENSATE |
| | REFRIGERANT LIQUID | | CONDENSER WATER RETURN |
| | REFRIGERANT HOT GAS | | REFRIGERANT SUCTION |
| | REVISION MARK | | NOTE MARK |
| | ACCESS PANEL IN CEILING (BY OTHERS) | | ACCESS PANEL IN WALL (BY OTHERS) |
| | POINT OF DISCONNECTION | | POINT OF NEW CONNECTION |


EQUIPMENT CALLOUT EQUIPMENT TYPE
 EQUIPMENT NUMBER

AIR TERMINAL CALLOUT AIR TERMINAL TYPE
 200 CFM IDENTIFIER & NUMBER
 AIR FLOW

THERMOSTAT CALLOUT Equipment Tag

DE PERE COMMUNITY CENTER
 AHU UPGRADE
 600 GRANT STREET, DE PERE, WI 54115

- GENERAL NOTES:**
- CONTRACTOR IS RESPONSIBLE TO VERIFY ALL SITE, FIELD AND BUILDING CONDITIONS PRIOR TO SUBMITTING BIDS AND COMMENCING WORK. IF THERE ARE ANY DISCREPANCIES BETWEEN DRAWINGS AND FIELD CONDITIONS, NOTIFY THE CONSTRUCTION MANAGER AND ARCHITECT/ENGINEER AND REQUEST CLARIFICATION.
- KEYED PLAN NOTES:**
- REMOVE SUPPLY FAN FROM EXISTING AIR-HANDLING UNIT. PREP THE AREA FOR NEW FAN ARRAY IMPLEMENTATION
 - REMOVE DX COOLING COIL FROM EXISTING AIR-HANDLING UNIT. REMOVE TWO (2) 2-1/8" REFRIGERANT SUCTION LINES AND TWO (2) 5/8" REFRIGERANT LIQUID LINES. EXISTING DRAIN PAN TO REMAIN.
 - REMOVE EXISTING AIR-COOLED CONDENSING UNIT AND CONCRETE PAD. PREP THE AREA FOR NEW CONCRETE PAD AND EQUIPMENT.



1 FIRST FLOOR DEMO PLAN
 1/8" = 1'-0"

ISSUANCE HISTORY

| | |
|---------------|----------|
| BID DOCUMENTS | 11/17/25 |
|---------------|----------|

SHEET REVISIONS

| | |
|--|--|
| | |
| | |
| | |

TITLE




FIRST FLOOR DEMO PLAN

| | |
|-------------|----------|
| JOB#: | 7735 |
| DRAWN BY: | MRL |
| CHECKED BY: | WPH |
| SCALE: | AS SHOWN |



M101

THE DRAWING IS THE EXCLUSIVE PROPERTY OF TWEETBROT MECHANICAL, AND WAS PREPARED FOR THE EXCLUSIVE USE OF TWEETBROT MECHANICAL. NO REPRODUCTION, OR DUPLICATION OF THIS DRAWING, IN PART OR WHOLE MAY BE MADE WITHOUT WRITTEN PERMISSION OF TWEETBROT MECHANICAL.



1 AHU CHILLED WATER COIL PIPING DETAIL
 NTS

2 AIR COOLED CHILLER PIPING DETAIL
 NTS

3 CHILLED WATER AIR CONTROL AND PUMPING PIPING DETAIL
 NTS

AIR COOLED WATER CHILLER SCHEDULE

| TAG | LOCATION | MANUFACTURER | MODEL NO. | NOMINAL CAPACITY (TONS) | ACTUAL CAPACITY (TONS) | REFRIGERANT | COMPRESSOR TYPE | STAGES | CHILLED WATER CONDITIONS | | | | FLUID | CONDENSER AMBIENT AIR TEMP. (°F) | EER | NPLV | TOTAL POWER INPUT (KW) | VOLTS/PH | MCA | MOCP | EMER. POWER (Y/N) | WEIGHT (LBS.) |
|-------|-----------|--------------|-----------|-------------------------|------------------------|-------------|-----------------|--------|--------------------------|----------|----------|--------------|------------------|----------------------------------|------|------|------------------------|----------|-----|------|-------------------|---------------|
| | | | | | | | | | GPM | EWI (°F) | LWT (°F) | WPD (FT. WG) | | | | | | | | | | |
| ACC-1 | SEE PLANS | TRANE | CGAM | 52 | 49.62 | R-454B | SCROLL | 4 | 106.3 | 56 | 44 | 19.2 | 35% PROP. GLYCOL | 95 | 11.5 | 17.2 | 51.6 | 208/3 | 251 | 300 | N | 4000 |

SCHEDULE NOTES:
 1. FURNISH WITH ELASTOMERIC ISOLATION PADS.
 2. PROVIDE WITH ELECTRIC HEATER FOR EVAPORATOR TUBE BUNDLE FREEZE PROTECTION. HEATER REQUIRES A SEPARATE 115 V, 20 AMP FIELD PROVIDED ELECTRICAL POWER CONNECTION.

PUMP SCHEDULE

| TAG | SERVICE | LOCATION | MANUFACTURER | MODEL | CONNECTION SIZE | | CAPACITY | | FLUID | DUTY POINT EFF. | IMPELLER SIZE (in.) | MOTOR RPM | HP | VOLTS/PH | VFD (Y/N) | EMER. POWER (Y/N) | WEIGHT (LBS.) |
|-----|---------|----------------|----------------|-----------|-----------------|-----------------|----------|------|---------------|-----------------|---------------------|-----------|----|----------|-----------|-------------------|---------------|
| | | | | | SUCTION (in.) | DISCHARGE (in.) | GPM | HEAD | | | | | | | | | |
| P-1 | ACC-1 | MECHANICAL 110 | BELL & GOSSETT | e-90 2AAC | 2 | 2 | 120 | 80 | 35% PP GLYCOL | 76.3% | 4.875 | 3,330 | 5 | 208/3 | Y | N | 85 |
| P-2 | ACC-1 | MECHANICAL 110 | BELL & GOSSETT | e-90 2AAC | 2 | 2 | 120 | 80 | 35% PP GLYCOL | 76.3% | 4.875 | 3,330 | 5 | 208/3 | Y | N | 85 |

SCHEDULE NOTES:
 1. FURNISH BOTH PUMPS WITH A TRIPLE DUTY VALVE.
 2. PROVIDE PUMP MOTOR WITH SHAFT GROUNDING RINGS.

COOLING COIL SCHEDULE

| TAG | LOCATION | COIL TYPE | CFM | MAX. VELOCITY (FPM) | AREA (SQ. FT.) | COIL SIZE H x W (IN.) | TOTAL CAP. MBH | SENSIBLE CAP. MBH | ENTERING AIR | | | | LEAVING AIR | | | | WATER COIL CONDITIONS | | | |
|------|----------|-----------|--------|---------------------|----------------|-----------------------|----------------|-------------------|--------------|------|------|------|-------------|---------|--------------|--------------|-----------------------|--------------|--------|-----|
| | | | | | | | | | DB | WB | DB | WB | ROWS | FINS/IN | APD (IN. WC) | EWI (DEG. F) | LWT (DEG. F) | WPD (FT. WC) | GLYCOL | |
| CC-1 | AHU-1 | CHW | 10,800 | 500 | 24.4 | PER AHU | 611.8 | 354.1 | 84.0 | 71.6 | 54.4 | 54.2 | 6 | 11 | 1 | 44.0 | 56.0 | 112.3 | 39.6 | 35% |

EXPANSION TANK SCHEDULE

| TAG | LOCATION | MANUFACTURER | MODEL | TANK VOLUME (GAL) | ACCEPTANCE VOLUME (GAL) | SIZE | | SIZE DETERMINATION (INFORMATIONAL ONLY) | | | | | | | | | | WEIGHT (LBS.) |
|------|----------------|----------------|--------|-------------------|-------------------------|----------|-------------|---|---------------------|---------------------|-------------------|----------------------|---------------------|----|--|--|--|---------------|
| | | | | | | DIA (IN) | HEIGHT (IN) | TEMP. MIN. (DEG. F) | TEMP. MAX. (DEG. F) | SYSTEM VOLUME (GAL) | FILL PRESS (PSIG) | MAX SYS PRESS (PSIG) | RELIEF PRESS (PSIG) | | | | | |
| ET-1 | MECHANICAL 110 | BELL & GOSSETT | HFT-30 | 4.4 | 2.5 | 11 | 14 | 44 | 100 | 200 | 15 | 70 | 70 | 20 | | | | |

SCHEDULE NOTES:
 1. EXPANSION TANK SHALL BE OF DIAPHRAGM TYPE AND VERTICAL ORIENTATION AND SUITABLE FOR 35% PROPYLENE GLYCOL.

BUFFER TANK SCHEDULE

| TAG | LOCATION | MANUFACTURER | MODEL | TANK VOLUME (GAL) | SIZE | | WEIGHT (LBS.) |
|------|----------------|--------------|-------------|-------------------|----------|-------------|---------------|
| | | | | | DIA (IN) | HEIGHT (IN) | |
| BT-1 | MECHANICAL 110 | JOHN WOOD | JBTR-22-130 | 130.0 | 24 | 75 | 350 |

SCHEDULE NOTES:
 1. TANK SHALL BE AN ASME RATED PRESSURE VESSEL DESIGNED, FABRICATED, TESTED, AND STAMPED IN ACCORDANCE WITH ASME BOILER AND PRESSURE VESSEL CODE

FAN ARRAY SCHEDULE

| TAG | SERVICE | LOCATION | MANUFACTURER | MODEL NO. | TOTAL AIRFLOW (CFM) | EXT. SP (IN. WC) | QTY. OF FANS | MHP (EA. FAN) | FAN OPERATING RPM | FAN MAXIMUM RPM | VOLTAGE/PH | EG MOTOR (Y/N) | VFD (Y/N) | EMEG. POWER (Y/N) | SINGLE FAN WEIGHT (LBS.) |
|-----|---------|----------|--------------|-----------|---------------------|------------------|--------------|---------------|-------------------|-----------------|------------|----------------|-----------|-------------------|--------------------------|
| | | | | | | | | | | | | | | | |

SCHEDULE NOTES:
 1. FAN ARRAY BULK-HEAD SIZE IS APPROX. 74" WIDE BY 50" TALL.
 2. PROVIDE BACKDRAFT DAMPER ON EACH INDIVIDUAL FAN IN THE ARRAY.
 3. PROVIDE CONTROL BOX THAT INCLUDES DISCONNECT SWITCH, CONTROL RELAYS, DIGITAL AND ANALOG INPUTS AND OUTPUTS, HAND-OFF-AUTO SWITCH, AND MANUAL SPEED CONTROLLER.
 5. INTERFACE FAN ARRAY CONTROLLER TO THE BUILDING AUTOMATION SYSTEM.

ISSUANCE HISTORY
 BID DOCUMENTS 11/17/25

SHEET REVISIONS

TITLE
 HVAC DETAILS & SCHEDULES

JOB#: 7735
 DRAWN BY: MRL
 CHECKED BY: WPH
 SCALE: AS SHOWN

M601

| |
|------------------------|
| ISSUANCE HISTORY |
| BID DOCUMENTS 11/17/25 |

| |
|-----------------|
| SHEET REVISIONS |
|-----------------|

TITLE
 HVAC SPECIFICATIONS &
 CONTROL SEQUENCES

JOB#: 7735
 DRAWN BY: MRL
 CHECKED BY: WPH
 SCALE: AS SHOWN

M901

HVAC SPECIFICATIONS:

GENERAL:
 PROJECT SHALL BE SITE VISITED TO VERIFY ACTUAL CONDITIONS. ALL WORK SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES AND REGULATIONS.

MECHANICAL CONTRACTOR SHALL PROVIDE AS-BUILT DRAWINGS, HVAC SYSTEM OPERATION AND MAINTENANCE MANUALS AND TRAINING TO THE OWNER'S MAINTENANCE PERSONNEL.

THE TEMPERATURE CONTROL SYSTEM SHALL BE TESTED, ADJUSTED AND CALIBRATED IN COMPLIANCE WITH SPS 384.0313. AIR AND HYDROIC SYSTEMS SHALL BE BALANCED IN ACCORDANCE WITH THE NATIONAL ENVIRONMENTAL BALANCING BUREAU (NEBB), AND SPS 384.0313. SUBMIT (1) ONE ELECTRONIC COPY OF AIR BALANCING REPORTS. SUBMIT (1) ONE ELECTRONIC COPY OF SHOP DRAWINGS FOR APPROVAL AND (1) ONE ELECTRONIC COPY OF OPERATION & MAINTENANCE MANUALS FOR ALL EQUIPMENT.

FIRESTOPPING SHALL BE PROVIDED AS REQUIRED TO MAINTAIN THE FIRE RESISTANCE RATING OF THE WALLS AND FLOORS PENETRATED BY THE HVAC SYSTEM COMPONENTS. FIRESTOPPING SHALL MEET ASTM E814 REQUIREMENTS.

CONCRETE PADS WILL BE PROVIDED FOR ALL HVAC EQUIPMENT THAT IS FLOOR SUPPORTED, UNLESS OTHERWISE SPECIFICALLY NOTED.

ROOMS WITH SPECIFIC PRESSURE RELATIONSHIP REQUIREMENTS SUCH AS LABORATORIES, OPERATING ROOMS AND ISOLATION ROOMS SHALL HAVE ALL WALL PIPING AND DUCTWORK PENETRATIONS SEALED.

WORK BY OTHERS:
 THE FOLLOWING WORK IS NOT PROVIDED BY THE MECHANICAL CONTRACTOR:
 ASBESTOS ABATEMENT.

LINE VOLTAGE POWER WIRING, MOTOR STARTERS, AND DISCONNECTS, UNLESS OTHERWISE SPECIFICALLY NOTED.

ACCESS PANELS IN THE GENERAL CONSTRUCTION TO PROVIDE SERVICE ACCESS TO HVAC SYSTEM COMPONENTS.

PAINTING OF HVAC SYSTEMS, UNLESS OTHERWISE SPECIFICALLY NOTED.

EXTERIOR CONCRETE PADS FOR SUPPORT OF EQUIPMENT ON GRADE, OR FOR ANCHORING OF UNDERGROUND TANKS, STRUCTURAL STEEL FOR SUPPORT OF ROOF MOUNTED HVAC EQUIPMENT, INCLUDING MISCELLANEOUS STEEL FOR ROOF OPENING FRAMING, POURING OF CONCRETE PADS FOR ALL FLOOR SUPPORTED HVAC EQUIPMENT SHALL BE PROVIDED BY THE MECHANICAL CONTRACTOR, UNLESS OTHERWISE SPECIFICALLY NOTED.

FIRE SUPPRESSION SYSTEMS FOR ANY AND ALL KITCHEN EXHAUST HOODS UNLESS OTHERWISE SPECIFICALLY STATED.

IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT:
 COORDINATE INSTALLATION OF IDENTIFYING DEVICES WITH COMPLETION OF COVERING AND PAINTING OF SURFACES WHERE DEVICES ARE TO BE INSTALLED. COORDINATE INSTALLATION OF IDENTIFYING DEVICES WITH LOCATIONS OF ACCESS PANELS AND DOORS.

EQUIPMENT LABELS
 PROVIDE ADHESIVE LABELS FOR MECHANICAL IDENTIFICATION, BLACK LETTER COLOR ON YELLOW BACKGROUND, MINIMUM LABEL SIZE SHALL NOT BE LESS THAN 2 INCHES. MINIMUM LETTER SIZE SHALL NOT BE LESS THAN 1/16 INCH.

INSTALL OR PERMANENTLY FASTEN LABELS ON EACH MAJOR ITEM OF MECHANICAL EQUIPMENT AND LOCATE EQUIPMENT LABELS WHERE ACCESSIBLE AND VISIBLE.

PIPE LABELS
 PREPRINTED, COLOR-CODED, WITH LETTERING INDICATING SERVICE, AND SHOWING FLOW DIRECTION, SELF-ADHESIVE TYPE, PRINTED PLASTIC WITH CONTACT-TYPE, PERMANENT-ADHESIVE BACKING.

INCLUDE IDENTIFICATION OF PIPING SERVICE USING SAME DESIGNATIONS OR ABBREVIATIONS AS USED ON THE DRAWINGS AND INCLUDE AN ARROW INDICATING FLOW DIRECTION. LETTERING SIZE SHALL BE AT LEAST 1-1/2 INCHES HIGH. FLOW DIRECTION ARROWS CAN BE SEPARATE FROM THE PIPE IDENTIFICATION LABEL TO INDICATE FLOW DIRECTION.

LOCATE PIPE LABELS WHERE PIPING IS EXPOSED OR ABOVE ACCESSIBLE CEILING IN FINISHED SPACES; MACHINE ROOMS; ACCESSIBLE MAINTENANCE SPACES SUCH AS SHAFTS, TUNNELS, AND PLENUMS; AND EXTERIOR EXPOSED LOCATIONS AS FOLLOWS:
 • AT LEAST ONCE IN EACH ROOM
 • NEAR EACH VALVE AND CONTROL DEVICE
 • NEAR EACH BRANCH CONNECTION, EXCLUDING SHORT TAKEOFFS FOR FIXTURES AND TERMINAL UNITS, WHERE FLOW PATTERN IS NOT OBVIOUS, MARK EACH PIPE AT BRANCH
 • NEAR PENETRATIONS THROUGH WALLS, FLOORS, CEILINGS, AND INACCESSIBLE ENCLOSURES
 • AT ACCESS DOORS, MANHOLES, AND SIMILAR ACCESS POINTS THAT PERMIT VIEW OF CONCEALED PIPING
 • NEAR MAJOR EQUIPMENT ITEMS AND OTHER POINTS OF ORIGINATION AND TERMINATION
 • SPACED AT MAXIMUM INTERVALS OF 20 FEET ALONG EACH RUN. REDUCE INTERVALS TO 10 FEET IN AREAS OF CONGESTED PIPING AND EQUIPMENT.

VALVE TAGS
 STAMPED OR ENGRAVED WITH 1/4-INCH LETTERS FOR PIPING SYSTEM ABBREVIATION AND 1/2-INCH NUMBERS. TAG MATERIAL SHALL BE BRASS, 0.032-INCH MINIMUM THICKNESS WITH PREDRILLED OR STAMPED HOLES FOR ATTACHMENT HARDWARE. FASTENERS SHALL BE BRASS WIRE-LINK OR BEADED CHAIN, OR S-HOOK.

INSTALL TAGS ON VALVES AND CONTROL DEVICES IN PIPING SYSTEMS, EXCEPT CHECK VALVES; VALVES WITH FACTORY-FABRICATED EQUIPMENT UNITS; SHUTOFF VALVES; AND HVAC TERMINAL DEVICES AND SIMILAR ROUGH-IN CONNECTIONS OF END-USE FIXTURES AND UNITS. LIST TAGGED VALVES IN A VALVE SCHEDULE.

VALVE SCHEDULES
 FOR EACH PIPING SYSTEM, ON 8-1/2-BY-11-INCH BOND PAPER, TABULATE VALVE NUMBER, PIPING SYSTEM, SYSTEM ABBREVIATION (AS SHOWN ON VALVE TAG), LOCATION OF VALVE (ROOM OR SPACE), NORMAL-OPERATING POSITION (OPEN, CLOSED, OR MODULATING), AND VARIATIONS FOR IDENTIFICATION. MARK VALVES FOR EMERGENCY SHUTOFF AND SIMILAR SPECIAL USES. VALVE SCHEDULE SHALL BE INCLUDED IN OPERATION AND MAINTENANCE DATA.

PIPE AND FITTINGS
GENERAL:
 PIPING SHALL BE REAMED AND THOROUGHLY CLEANED OF SCALE AND DIRT BEFORE BEING INSTALLED. PROVIDE VENTS AT ALL HIGH PIPING POINTS AND DRAINS WITH HOSE CONNECTION AT LOW POINTS. PROVIDE NIBCO LD2000 BUTTERFLY VALVES, ANSI 200, WITH BUNA SEAT, STAINLESS STEEL SHAFT AND DISC AND MULTI-POSITION HANDLE. BALL VALVES SHALL BE FULL PORT NIBCO TYPE S-585.

PIPING CONSTRUCTION AND INSULATION:
 REFER TO THE STANDARD PIPING MATRIX ON THE PLAN DOCUMENTS.

FIBERGLASS INSULATION SHALL BE 3 LBS/CU FT, DENSITY, ANSI/ASTM C547 'K' VALUE OF 0.24 AT 75 DEG. F MEAN TEMPERATURE, WITH A FLAME SPREAD RATING OF 25 OR LESS AND A SMOKE DEVELOPED RATING 50 OR LESS. PROVIDE WHITE KRAFT FACED PIPING JACKET WITH SELF-HEALING JOINTS. PROVIDE ZESTON PRE-MOLDED PVC INSULATION FITTINGS FOR ALL PIPING FITTINGS. LABEL PIPING TO IDENTIFY THE HEATING OR COOLING SYSTEM, WITH FLOW DIRECTIONAL ARROWS.

VARIABLE FREQUENCY DRIVES
 PROVIDE ABB ACH500 OR APPROVED EQUAL, VARIABLE FREQUENCY DRIVES WITH DRIVE BY-PASS CONTROLLER. DRIVE SHALL BE UL LISTED, FULLY DIGITAL PWM DESIGN WITH DIODE FRONT END AND IGBT TRANSISTORIZED OUTPUT. PROVIDE DRIVE WITH A NEMA 1 ENCLOSURE, CIRCUIT BREAKER TYPE DISCONNECT SWITCH, BACNET INTERFACE BOARD, FRONT PANEL DIGITAL KEYPAD PROGRAMMING, WITH HAND-OFF-AUTO SELECTIONS AND MANUAL SPEED CONTROL. THE DRIVE SHALL HAVE PREPROGRAMMED PROTECTION FOR OVER CURRENT, SHORT CIRCUIT, OVER VOLTAGE, UNDER VOLTAGE, LOSS OF ANALOG INPUT, MOTOR OVERLOAD AND INVERTER OVERLOAD. PROVIDE 36 MONTH PARTS AND LABOR WARRANTY FROM DATE OF SHIPMENT. PROVIDE VFD START-UP FROM FACTORY AUTHORIZED TECHNICIAN. PROVIDE (1) ELECTRONIC COPY OF THE VFD START-UP REPORT.

PACKAGED AIR-COOLED WATER CHILLERS
 PROVIDE AIR -COOLED WATER CHILLERS AS SCHEDULED ON THE DRAWINGS. PROVIDE CHILLERS WITH A ONE-YEAR, FULL UNIT WARRANTY. PROVIDE CHILLER FACTORY START-UP WITH A START-UP REPORT.

ACCEPTABLE MANUFACTURERS: CARRIER, DAIKIN, TRANE AND YORK.
 PROVIDE A FACTORY ASSEMBLED AND TESTED PACKAGED AIR-COOLED WATER CHILLER COMPLETE WITH, HERMETIC COMPRESSORS, AIR COOLED CONDENSERS, EVAPORATOR, FLOW SWITCH, REFRIGERATION CONTROLS AND CONTROL PANEL. UNIT SELECTION SHALL BE BASED ON A GLYCOL/WATER SOLUTION AS INDICATED ON THE PLAN SCHEDULES. UNIT EFFICIENCY RATINGS SHALL BE NOT LESS THAN THE ASHRAE 90.1 EFFICIENCY RATINGS. CONSTRUCTION AND RATING SHALL BE IN ACCORDANCE WITH ARI 550.

INSULATE EVAPORATOR AND REFRIGERATION PIPING TO PREVENT CONDENSATION. PROVIDE HEAT TAPE WITH THERMOSTAT TO PROTECT THE EVAPORATOR FROM FREEZING DOWN TO AN AMBIENT TEMPERATURE OF -20 DEG. F FOR CHILLERS THAT DO NOT UTILIZE GLYCOL FOR FREEZE PROTECTION. PROVIDE CHILLER WITH SINGLE POINT ELECTRICAL POWER CONNECTION, AND PREWIRED UNIT MOUNTED DISCONNECT SWITCH. CONDENSER SHALL BE CONSTRUCTED WITH ALUMINUM FINS MECHANICALLY SECURED TO COPPER TUBING. PROVIDE MICROPROCESSOR CONTROL WITH DIGITAL PROGRAMMING TO DETERMINE CHILLER FUNCTION, START/STOP AND ALARMS AND BACNET COMMUNICATION INTERFACE.

HVAC SPECIFICATIONS CONTINUED:

INLINE PUMPS
 FURNISH AND INSTALL INLINE PUMPS AS SHOWN ON THE PLANS.

ACCEPTABLE MANUFACTURERS: BELL & GOSSETT, TACO, OR ARMSTRONG.

THE PUMPS SHALL BE CLOSE-COUPLED, INLINE FOR VERTICAL OR HORIZONTAL INSTALLATION, IN CAST IRON BRONZE FITTED (OR ALL BRONZE) CONSTRUCTION SPECIFICALLY DESIGNED FOR QUIET OPERATION, SUITABLE STANDARD OPERATIONS AT 250' F AND 175 PSIG WORKING PRESSURE. THE PUMP INTERNALS SHALL BE CAPABLE OF BEING SERVICED WITHOUT DISTURBING PIPING CONNECTIONS.

THE MOTOR BEARINGS SHALL SUPPORT THE SHAFT VIA HEAVY-DUTY PERMANENTLY LUBRICATED BALL BEARINGS.

THE PUMP MOTOR SHALL BE A SINGLE SPEED MOTOR WITH PERMANENTLY LUBRICATED OR GREASE-LUBRICATED BALL BEARINGS WITH ADJUSTABLE ALIGNMENT. MOTORS SHALL BE NON-OVERLOADING AT ANY POINT ON THE PUMP CURVE AND SHALL MEET NEMA SPECIFICATIONS.

THE PUMP SHALL BE FACTORY ASSEMBLED AND TESTED, THOROUGHLY CLEANED, AND PAINTED WITH ONE COAT OF MACHINERY ENAMEL PRIOR TO SHIPMENT. A SET OF INSTALLATION INSTRUCTIONS SHALL BE INCLUDED WITH THE PUMP. PUMPS SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS.

PROVIDE PRESSURE GAUGES PIPED AND VALVED FOR MEASURING BOTH SUCTION AND DISCHARGE PRESSURE, COMPLETE WITH SHUTOFF GAUGE VALVES.

FURNISH AND INSTALL TRIPLE DUTY VALVES ON THE DISCHARGE SIDE OF ALL PUMPS AND FURNISH AND INSTALL A LINE SIZE SHUT-OFF VALVE ON THE SUCTION SIDE OF ALL PUMPS.

REDUCTION FROM LINE SIZE TO PUMP CONNECTION SIZE SHALL BE MADE WITH ECCENTRIC REDUCERS ATTACHED TO THE PUMP WITH TOPS FLAT TO ALLOW CONTINUITY OF FLOW.

PROVIDE AN ADEQUATE NUMBER OF ISOLATION VALVES FOR SERVICE AND MAINTENANCE OF THE SYSTEM AND ITS COMPONENTS.

POWER WIRING, AS REQUIRED, SHALL BE THE RESPONSIBILITY OF THE ELECTRICAL CONTRACTOR. ALL WIRING SHALL BE PERFORMED PER MANUFACTURER'S INSTRUCTION AND APPLICABLE STATE, FEDERAL, AND LOCAL CODES.

CONTROL WIRING FOR REMOTE MOUNTED SWITCHES AND SENSOR / TRANSMITTERS SHALL BE THE RESPONSIBILITY OF THE CONTROL CONTRACTOR. ALL WIRING SHALL BE PERFORMED PER MANUFACTURER'S INSTRUCTIONS AND APPLICABLE STATE, FEDERAL, AND LOCAL CODES.

AIR CONTROL
 AIR SEPARATOR SHALL BE INSTALLED IN RETURN PIPING AND SHALL BE BELL AND GOSSETT, ROLAIR/ROL FOR PIPING SIZES LARGER THAN 2", AND IN-LINE AIR/ROL FITTINGS FOR PIPING SIZES 2" AND UNDER. THE UNIT SHALL BE CONSTRUCTED FOR 125 PSI WORKING PRESSURE AND STAMPED WITH THE ASME 'U' SYMBOL. THE REMOVABLE GALVANIZED SYSTEM STRAINER SHALL BE 3/16" DIAMETER PERFORATIONS AND A FREE AREA OF NOT LESS THAN FIVE TIMES THE AREA OF THE CONNECTING PIPE. THE CONTRACTOR SHALL REMOVE AND CLEAN THE STRAINER AFTER THE INITIAL CLEANING AND AGAIN IN 30 DAYS. A BLOWDOWN CONNECTION SHALL BE PROVIDED TO FACILITATE ROUTINE CLEANING.

PIPE AIR OUTLET TO COMPRESSION TANK, PITCHING UP TO TANK. CONNECT AIR CONTROL LINE TO TANKS USING BELL AND GOSSETT 'AIR/ROL' TANK FITTINGS. THE TANK FITTING SHALL INCLUDE A MANUAL VENT.

EXPANSION TANKS
 TANKS SHALL BE CONSTRUCTED ACCORDING TO REQUIREMENTS OF ASME FOR 125 PSI SERVICE. SECURELY SUPPORT TANKS IN PLACE WHERE SHOWN.

PROVIDE BELL & GOSSETT 'AIR/ROL' TANK FITTINGS, AIR CHARGING DRAIN VALVE AND GAUGE GLASSES ON TANK.

EXPANSION TANKS SHALL BE DIAPHRAGM, BLADDER OR STANDARD COMPRESSION TYPE TANKS AS SCHEDULED.

GLYCOL FILL STATIONS
 THE HYDROIC SYSTEM FEEDER SHALL BE AXIOM INDUSTRIES LTD, MODEL DMF300. SYSTEM SHALL INCLUDE: 17 US GALLON STORAGE/MIXING TANK WITH COVER; PUMP SUCTION HOSE WITH INLET STRAINER, PRESSURE PUMP WITH THERMAL CUTOFF; INTEGRAL PRESSURE SWITCH; INTEGRAL CHECK VALVE, CORO AND PLUG; PRE-CHARGED ACCUMULATOR TANK WITH EPDM DIAPHRAGM; MANUAL DIVERTER VALVE FOR PURGING AIR AND AGITATING ELEMENTS OF STORAGE TANK; PRESSURE REGULATING VALVE COMPLETE WITH PRESSURE GAUGE; BUILT IN CHECK VALVE; UNION CONNECTION: 1/4" X 3/8" LONG FLEXIBLE HOSE WITH CHECK VALVE; LOW LEVEL PUMP CUTOFF.

PRESSURE PUMP SHALL BE CAPABLE OF RUNNING DRY WITHOUT DAMAGE. POWER SUPPLY 115/60/1 0.7A. UNIT SHALL BE COMPLETELY PRE-ASSEMBLED AND CERTIFIED BY RECOGNIZED TESTING AGENCY TO CSA STANDARD C22.2 NO 68.

ADDITIONAL LOW LEVEL ALARM PANEL TO BE PROVIDED WITH THE HYDROIC SYSTEM FEEDER. THE LOW LEVEL ALARM PANEL SHALL PROVIDE A SELECTABLE AUDIBLE ALARM AND ADDITIONAL REMOTE MONITORING DRY CONTACTS.

AHU COOLING COILS
 THE UNIT COOLING COILS SHALL BE EQUAL TO SIZES AND CAPACITIES SCHEDULED. MOUNT COILS IN THE CASING TO BE ACCESSIBLE FOR SERVICE AND TO BE REMOVABLE FROM THE SIDE OF THE UNIT. COIL U-BENDS SHALL BE WITHIN THE UNIT INSULATED CASING. SUPPORT COILS ALONG THEIR ENTIRE LENGTH WITHIN THE CASING AND PITCH FOR PROPER DRAINAGE.

LIMIT COIL FACE VELOCITY TO 500 FEET PER MINUTE, OR OTHERWISE AS REQUIRED TO PREVENT MOISTURE CARRYOVER.

CONSTRUCT EVAPORATOR COILS WITH COPPER TUBES AND ALUMINUM FINS. FINS SHALL BE MECHANICALLY BONDED TO THE TUBES. COILS SHALL BE INTERTWINED TYPE FOR UNIT WITH MULTIPLE REFRIGERANT CIRCUITS. FACE SPLIT COILS ARE NOT ACCEPTABLE.

COOLING COIL DRAIN PAN SHALL BE STAINLESS STEEL, PITCHED TO A DRAIN CONNECTION.

INCLUDE CONTROL COMPONENTS REQUIRED FOR PROPER OPERATION OF UNITS AND AUXILIARY EQUIPMENT LOCATED WITHIN THE UNIT. INCLUDE THE FOLLOWING:

- 24 VAC OUTPUT, FACTORY-INSTALLED AND WIRED CONTROL TRANSFORMER FOR INTERNAL CONTROL POWER REQUIREMENTS
- RELAYS AS REQUIRED TO ACHIEVE SPECIFIED OPERATION
- NON-FUSED, WEATHERPROOF, PREWIRED DISCONNECT SWITCH
- PROVIDE UNITS WITH ONE EXTRA SET OF FAN BELTS AND ONE EXTRA SET OF CONTROL FUSES.

TEMPERATURE CONTROLS
 PROVIDE TRIDUIM, JOHNSON CONTROLS, SIEMENS, AUTOMATED LOGIC OR DELTA DIRECT DIGITAL CONTROL (DDC) SYSTEM CONSISTING OF THERMOSTATS, SENSORS, CONTROL VALVES AND DAMPER OPERATORS, OPERATORS, INTERFACE EQUIPMENT AND OTHER ELECTRONIC EQUIPMENT TO COMPLETE THE CONTROL FUNCTIONS, AS SPECIFIED. COORDINATE TYPE OF SPACE TEMPERATURE SENSOR CONTROL FUNCTION WITH THE OWNER.

PROVIDE DDC CONTROL OPERATING INFORMATION CONSISTING OF SYSTEM CONTROL DRAWINGS, WIRING DIAGRAMS, DETAILED SEQUENCE OF HVAC COMPONENT SYSTEM OPERATION, SUMMARY LISTING OF DDC CONTROL POINTS, ENGINEERING DATA FOR EACH CONTROL SYSTEM COMPONENT WITH SIZE AND SELECTION. SUBMIT ONE ELECTRONIC COPY OF DDC SUBMITTALS FOR APPROVAL.

AUTOMATIC TEMPERATURE CONTROL VALVES AND AUTOMATIC DAMPERS SHALL BE PROVIDED BY THE TEMPERATURE CONTROL CONTRACTOR. PROVIDE CONTROL VALVES AND DAMPER ACTUATORS. COOLING 3-WAY CONTROL VALVES SHALL BE NORMALLY OPEN WITH A 1.2 MINIMUM CV RATING.

ALL LOW VOLTAGE WIRING SHALL BE PLENUM RATED THERMOSTAT WIRE. ALL LINE VOLTAGE WIRING REQUIRED TO COMPLETE THE DDC CONTROL SYSTEM, SUCH AS ELECTRICAL INTERLOCKS, SHALL BE RUN IN THIN WALL CONDUIT.

ALL SETPOINTS DEFINED WITHIN THE SEQUENCE OF OPERATIONS SHALL BE FULLY ADJUSTABLE VIA THE BAS SYSTEM USER INTERFACE.

EXECUTION
 THIS CONTRACTOR SHALL DO ALL CUTTING NECESSARY FOR THE PASSAGE OF PIPE. THIS CONTRACTOR SHALL TAKE ALL NECESSARY PRECAUTIONS TO PROTECT HIS WORK FROM DAMAGE OR INJURY UNTIL THE COMPLETION AND FINAL ACCEPTANCE OF HIS WORK.

THIS HVAC CONTRACTOR MUST INSTRUCT THE OWNER AND HIS REPRESENTATIVES IN THE PROPER OPERATING TECHNIQUES OF THE SYSTEM. THE CONTRACTOR SHALL PROVIDE OWNER WITH OPERATING & MAINTENANCE MANUALS.

THE CONTRACTOR MUST INSTALL PIPING, DUCTWORK AND EQUIPMENT TO PREVENT TRANSMISSION OF NOISE.

THE HEATING CONTRACTOR SHALL GUARANTEE THE ENTIRE SYSTEM AGAINST ALL DEFECTS FOR A PERIOD OF ONE (1) YEAR FROM DATE OF FINAL ACCEPTANCE.

HVAC CONTROL SEQUENCES

CHILLED WATER - AIR COOLED PACKAGED CHILLER
GENERAL:
 THE CHILLER PLANT SYSTEM SHALL BE CONTROLLED BY A DEDICATED DDC CONTROLLER OR COMBINATION OF CONTROLLERS CAPABLE OF STAND-ALONE OPERATION IF THE BAS NETWORK CONNECTION IS LOST. THIS CAN BE ACCOMPLISHED BY THE ON-BOARD CHILLER MOUNTED DDC CONTROLLER IF THE CHILLER IS PROVIDED WITH AN ON-BOARD CONTROLLER.

PROVIDE ALL SENSORS, RELAYS, CONTROL CONTACTORS AND WIRING NEEDED TO ACCOMPLISH THE BELOW LISTED SEQUENCE OF OPERATION. ALL CONTROL SETPOINTS AND RESET RANGES SHALL BE ADJUSTABLE.

CHILLED WATER PUMP CONTROL:
 WHEN A SINGLE CHILLED WATER PUMP IS PROVIDED, THE PRIMARY/STAND-BY SEQUENCE SHALL BE DISREGARDED.

THE CHILLED WATER PUMPS SHALL BE CONTROLLED VIA THE BAS.

WHEN THE OUTSIDE AIR TEMPERATURE RISES ABOVE 55 DEG. F, THE PRIMARY/LEAD CHILLED WATER PUMP SHALL START AND RUN. WHEN THE OUTSIDE AIR TEMPERATURE FALLS BELOW 55 DEG. F, OPERATION OF THE PRIMARY/LEAD PUMP FOR A CONTINUOUS DURATION OF 30 SECONDS, AN ALARM SIGNAL SHALL BE RECEIVED AT THE BAS. THE BAS SHALL TURN OFF THE PRIMARY/LEAD PUMP AND TURN ON THE SECONDARY/LAG PUMP. PROOF OF PUMP OPERATION SHALL BE PROVIDED VIA A CURRENT SENSOR SWITCH ON EACH PUMP WITH ITS CONTROL VALVES SET TO NORMAL PUMP OPERATING AMP DRAW RANGE. ALTERNATIVELY, PROOF OF PUMP OPERATION MAY BE OBTAINED THROUGH OUTPUTS ON THE PUMP VFD (IF PROVIDED).

WHEN THE OUTSIDE AIR TEMPERATURE DROPS BELOW 55 DEG. F, THE PRIMARY/LEAD CHILLED WATER PUMP SHALL STOP.

CHILLER CONTROL:
 WHEN THE OUTSIDE AIR TEMPERATURE RISES ABOVE 55 DEG. F, AND THE LEAD CHILLED WATER PUMP FLOW HAS BEEN PROVIDED VIA THE PUMP CURRENT SENSOR, THE BAS SHALL ENABLE THE CHILLER TO RUN AND PROVIDE CHILLED WATER TEMPERATURE CONTROL. THIS SHALL BE ACCOMPLISHED VIA A HARD-WIRED CONTROL INTERFACE BETWEEN THE BAS AND THE CHILLER CONTROLS.

THE CHILLED WATER SUPPLY TEMPERATURE SETPOINT SHALL BE INTERNALLY SET THROUGH THE CHILLER ON-BOARD CONTROL SEQUENCE BUT SHALL BE RESET VIA THE BAS INTERFACE. THIS SHALL BE ACCOMPLISHED VIA A HARD-WIRED CONTROL INTERFACE BETWEEN THE BAS AND THE CHILLER CONTROLS. THE CHILLED WATER TEMPERATURE SETPOINT SHALL BE SET TO THE LEAVING CHILLED WATER SUPPLY TEMPERATURE AS INDICATED ON THE CHILLER SCHEDULE.

CHILLED WATER TEMPERATURE SETPOINT RESET SHALL BE BASED ON OUTSIDE AIR TEMPERATURE AND SHALL BE BASED ON THE FOLLOWING REST SCHEDULE:

| | |
|-----------|--------------------------------|
| OAT | CHWS TEMP |
| 55 DEG. F | +6 DEG. F OVER SCHEDULED VALUE |
| 70 DEG. F | SCHEDULED VALUE |

THE UNIT MOUNTED CHILLER CONTROLLER SHALL STAGE UNIT COMPRESSORS AND/OR MODULATE COMPRESSOR SPEED AND CONDENSER FANS TO REGULATE CAPACITY CONTROL TO MAINTAIN CHILLED WATER SUPPLY TEMPERATURE SETPOINT.

WHEN THE OUTSIDE AIR TEMPERATURE DROPS BELOW 55 DEG. F, THE CHILLER SHALL BE DISABLED.

A HARD-WIRED ALARM INTERFACE FROM THE BAS TO THE CHILLER SHALL ANNOUNCE AN ALARM CONDITION IF THE CHILLER EXPERIENCES A PROBLEM. THE BAS SHALL ALSO INDICATE A SOFTWARE ALARM SHOULD THE CHILLER BE ENABLED TO RUN, AND IF THE CHILLED WATER SETPOINT TEMPERATURE CANNOT BE MAINTAINED FOR A PERIOD OF 60 MINUTES CONTINUOUS.

BAS POINTS:

- CHILLED WATER PUMP START/STOP (EACH PUMP)
- CHILLED WATER PUMP STATUS (EACH PUMP - VIA CURRENT SENSOR OR VFD)
- CHILLER ENABLE/DISABLE
- CHILLED WATER SETPOINT RESET
- CHILLER GENERIC ALARM
- CHILLED WATER SUPPLY TEMPERATURE
- CHILLED WATER RETURN TEMPERATURE
- FAILURE TO MAINTAIN CHILLED WATER SUPPLY TEMPERATURE (SOFTWARE)

AS AN ALTERNATIVE, THE BAS MAY INTERFACE TO THE UNIT MOUNTED CHILLER CONTROLS VIA A BACNET INTERFACE FOR ALL POINTS EXCEPT FOR CHILLER ENABLE/DISABLE.

AIR HANDLING UNIT - CHILLED WATER COIL
 CONTROL CONTRACTOR SHALL PROVIDE A DDC CONTROLLER, THERMOSTAT, SUPPLY AIR TEMPERATURE SENSOR AND ALL REQUIRED CONTROL WIRING TO PROVIDE COIL FUNCTIONALITY AS SPECIFIED HEREIN. ALSO PROVIDE A FILTER DIFFERENTIAL PRESSURE SWITCH FOR FILTER MONITORING, A HIGH-LEVEL CONDENSATE FLOAT SWITCH (OR WATER SENSOR IN THE AUXILIARY DRAIN PAN - WHEN INDICATED), AND A CURRENT SENSOR SWITCH WITH ITS CONTROL VALVE SET TO NORMAL FAN OPERATING AMP DRAW RANGE.

FURNISH A MODULATING, NORMALLY OPEN 3-WAY CONTROL VALVE FOR FAN COIL CHILLED WATER COIL CONTROL.

UPON A RISE IN ROOM TEMPERATURE ABOVE THE THERMOSTAT SETPOINT OF 75 DEG. F, THE DDC CONTROLLER SHALL MODULATE THE 3-WAY CHILLED WATER TEMPERATURE CONTROL VALVE OPEN, ON A DROP IN SPACE TEMPERATURE BELOW THE ROOM THERMOSTAT SETPOINT THE REVERSE SHALL OCCUR.

BAS POINTS:

- SUPPLY AIR TEMPERATURE
- ROOM THERMOSTAT SETPOINT
- ROOM TEMPERATURE
- COOLING COIL VALVE POSITION
- HIGH CONDENSATE LEVEL (OR WATER DETECTION IN AUXILIARY DRAIN PAN)
- ROOM HIGH TEMPERATURE ALARM (SOFTWARE)
- ROOM LOW TEMPERATURE ALARM (SOFTWARE)

| MECHANICAL PIPING APPLICATION SCHEDULE - (DIVISION 23) | | | | | | | | | | | | | | | | | |
|--|---------------------------------|---------------|-------------------------------|------------------------------------|-----------------------------|-------------------|------------------|------------|--------------|-------------|-----------|------------------|------------------|-----------------------|---|-------|--|
| Profile | | Application | | | | | Piping | | | Valves | | Hangers | Insulation | | | Notes | |
| Tag | System | Size | Max Operating Pressure (PSIG) | Max Operating Temperature (deg. F) | Location | Pipeline Material | Fitting Material | Joint Type | Flange Class | Type | Class | Hanger Sizing | Type | Thickness (IECC 2015) | Jacketing | | |
| CHW | Chilled Water | 1/2" - 1 1/4" | 150 | 60 | Concealed | Copper Type L B88 | Wrought Copper | Soldered | N/A | Not allowed | N/A | Over Size | Polyisocyanurate | 1/2" | ASJ | | |
| | | | | | Accessible | | | ProPress | N/A | Ball | 150 | Over Size | Polyisocyanurate | 1/2" | ASJ | | |
| | | | | | Exterior | | | Soldered | N/A | Ball | 150 | Over Size | Polyisocyanurate | 1" | VentureClad | | |
| | Chilled Water | 1-1/2" - 2" | 150 | 60 | Concealed | Copper Type L B88 | Wrought Copper | Soldered | N/A | Not allowed | N/A | Over Size | Polyisocyanurate | 1" | ASJ | | |
| | | | | | Accessible | | | ProPress | N/A | Ball | 150 | Over Size | Polyisocyanurate | 1" | ASJ | | |
| | | | | | Exterior | | | Soldered | N/A | Ball | 150 | Over Size | Polyisocyanurate | 1-1/2" | VentureClad | | |
| Chilled Water | 2-1/2" and up | 150 | 60 | Concealed | Black Steel SCH 40 A53B ERW | Carbon Steel A234 | Welded | 150 | Not allowed | N/A | Over Size | Polyisocyanurate | 1" | ASJ | | | |
| | | | | Accessible | | | Grooved | 150 | Butterfly | 150 | Over Size | Polyisocyanurate | 1" | ASJ | Valve sizes 8" and larger require gear operator | | |
| | | | | Exterior | | | Welded/Grooved | 150 | Butterfly | 150 | Over Size | Polyisocyanurate | 1-1/2" | VentureClad | | | |
| D | Condensate Drain (Cooling Coil) | 3/4" - 3" | 15 | 60 | Concealed | Type L Copper | Wrought Copper | Soldered | N/A | | | | | | | | |
| | | | | | Accessible | | | N/A | | | | | | | | | |
| | | | | | Exterior | | | N/A | | | | | | | | | |

EXHIBIT C


EXISTING SITE CONDITIONS



CONCRETE SIDEWALK
REMOVAL AND REPLACEMENT
(IF REQUIRED)



ASPHALTIC CONCRETE PAVEMENT
REMOVAL AND REPLACEMENT
(IF REQUIRED)



10'



ENGINEERING DIVISION
925 S. SIXTH ST
DE PERE, WI 54115
OFFICE: 920-339-4061
EMAIL:
DPPUBWRKS@DEPEREWI.GOV

| |
|---|
| EXHIBIT C EXISTING SITE CONDITIONS |
| PROJECT: 26-18 COMMUNITY CENTER CHILLER UPGRADE |
| DATE: 02/24/2026 BY: KAD CHECKED: EPR |