

CITY OF DE PERE

Public Works - Engineering Department

925 S. Sixth Street, De Pere, WI 54115 | 920-339-4061 | www.de-pere.org

January 24, 2020



ADDENDUM NO. 1
PROJECT 20-11
FIRE STATION #1 BOILER REPLACEMENT

TO: Prospective Bidders

FROM: City of De Pere

Notice is hereby given that the contract documents for the Project 20-11 are amended as hereinafter set forth. If you will be submitting a bid for Project 20-11, you must sign this addendum and include it with your submittal.

This addendum consists of 1 page.

CHANGES TO GENERAL REQUIREMENTS


- Under Section 01 10 00, Summary of Work, 1.6, insert the following:
"B. The following special provisions are included with the project.
 - Remove the existing ½ inch back flow preventer and replace with a new ¾ inch back flow preventer.
 - Install two (2) each, six (6) inch motorized back draft dampers in the six (6) inch combustion air intake for the boilers."

Sincerely,

DEPARTMENT OF PUBLIC WORKS

Handwritten signature of Eric P. Rakers in blue ink.

Eric P. Rakers, P.E.
City Engineer



Acknowledged by: _____ Date: _____